

Miller, Diane M. (CDC/NIOSH/EID)

From: mwheeler@vopf.com
Sent: Friday, February 13, 2009 12:31 PM
To: NIOSH Docket Office (CDC)
Cc: Chen, Jihong (Jane) (CDC/NIOSH/EID) (CTR)
Subject: 141 - FFUS Comments

Name
Captain Mike Wheeler

Organization
Park Forest Fire Department

Email
mwheeler@vopf.com

Address
156 Indianwood Boulevard
Park Forest, Illinois 60466
USA

Comments
In your comments regrading pre-plan information. An important piece of information related to abandoned commercial/industrial buildings would be the presence of fire doors, especially guillotine style doors. These doors can obstruct firefighter egress and cut off their water supply. It will also affect the RIT team's strategy and their ability to reach firefighters reporting a mayday.