

Dragon, Karen E. (CDC/NIOSH/EID)

From: james.scott@utoronto.ca
Sent: Friday, July 08, 2011 12:43 PM
To: NIOSH Docket Office (CDC)
Subject: 238 - NIOSH Indoor Environmental Quality (IEQ) Alert Comments

Name
James Scott

Organization
School of Public Health, University of Toronto

Email
james.scott@utoronto.ca

Address
223 College Street
Toronto, ON M5T 1R4
Canada

Comments

The comment negating the value of post-remediation sampling ("clearance sampling") is generally true with the exception of high-risk health-care settings. Here, there is good agreement in the infection control community of the value of post-remediation sampling for reasons of patient safety.