

Model Aquatic Health Code

Draft Hygiene Facilities Module CODE Sections Modified after the First 60-day Review that Closed for Public Comment on 12/29/2011

Informational Copy: NOT Currently Open for Public Comment

This version of the MAHC Hygiene Facilities Module has been modified based on the first round of public comments received. It is being re-posted so users can view how it was modified but is not currently open to public comment. The complete draft MAHC, with all of the individual module review comments addressed will be posted again for a final review and comment before MAHC publication. This will enable reviewers to review modules in the context of other modules and sections that may not have been possible during the initial individual module review. The public comments and MAHC responses can be viewed on the web at <http://www.cdc.gov/healthywater/swimming/pools/mahc/structure-content/index.html>

The MAHC committees appreciate your patience with the review process and commitment to this endeavor as we all seek to produce the best aquatic health code possible.

This information is distributed solely for the purpose of pre dissemination public viewing under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy.

MAHC Hygiene Facilities Module Abstract

Swimmer hygiene is a critical component that plays a role in documented waterborne disease outbreaks and poor water quality. The Hygiene Facilities Module is a first step towards improving swimmer hygiene and facility water quality to reduce the associated health effects. The Hygiene Facilities Module contains requirements primarily for new or modified construction that include:

- 1) Minimum distances for hygiene facilities from aquatic venues.
- 2) Newly defined diaper-changing stations.
- 3) Implementation of rinse vs. cleansing showers.

MAHC Table of Contents

The following chart shows the context of the Hygiene Facilities Design, Construction, Operation and Maintenance in the overall Model Aquatic Health Code's Strawman (<http://www.cdc.gov/healthywater/pdf/swimming/pools/mahc/structure-content/mahc-strawman.pdf>).

1.0	Preface
2.0	User Guide
3.0	Definitions
4.0	Design Standards and Construction
5.0	Operation and Maintenance
6.0	Policies and Management
7.0	Index
8.0	Annexes
9.0	Summary of Changes

4.0 Design Standards and Construction

- 4.1 Plan Submittal
- 4.2 Materials
- 4.3 Equipment Standards
- 4.4 Pool Operation and Facility Maintenance [N/A]
- 4.5 Pool Structure (Shell)
- 4.6 Indoor/Outdoor Environment
- 4.7 Recirculation and Water Treatment
- 4.8 Decks and Equipment
- 4.9 Filter/Equipment Room
- 4.10 Hygiene Facilities (Bathhouse)**
 - 4.10.1 General**
 - 4.10.2 Location**
 - 4.10.3 Design and Construction**
 - 4.10.4 Plumbing Fixture Requirements**

- 4.10.4.1 **General**
- 4.10.4.2 **Cleansing Showers**
- 4.10.4.3 **Rinse Showers**
- 4.10.4.4 **All Showers**
- 4.10.4.5 **Diaper-Changing Stations**
- 4.10.4.6 **Non-Plumbing Fixture Requirements**
- 4.10.5 **Provision of Suits, Towels, and Shared Equipment**
- 4.10.6 **Foot Baths**
- 4.10.7 **Sharps**
- 4.11 Water Supply/Wastewater Disposal
- 4.12 Specific Venues - Special Requirements

5.0 Operation and Maintenance

- 5.1 Plan Submittal [N/A]
- 5.2 Materials [N/A]
- 5.3 Equipment Standards [N/A]
- 5.4 Pool Operation and Facility Maintenance
- 5.5 Pool Structure (Shell)
- 5.6 Indoor/Outdoor Environment
- 5.7 Recirculation and Water Treatment
- 5.8 Decks and Equipment
- 5.9 Filter/Equipment Room
- 5.10 **Hygiene Facilities (Bathhouse)**
 - 5.10.1 **General**
 - 5.10.2 **Location**
 - 5.10.3 **Design and Construction**
 - 5.10.4 **Plumbing Fixture Requirements**
 - 5.10.4.1 **General**
 - 5.10.4.2 **Cleansing Showers**
 - 5.10.4.3 **Rinse Showers**
 - 5.10.4.4 **All Showers**
 - 5.10.4.5 **Diaper-Changing Stations**
 - 5.10.4.6 **Non-Plumbing Fixture Requirements**
 - 5.10.5 **Suits and Towels**
 - 5.10.6 **Foot Baths**
 - 5.10.7 **Sharps**

Acronyms in this Module:

AHJ	authority having jurisdiction
ASTM	American Society for Testing and Materials
ICBO	International Council of Building Officials
IPC	International Plumbing Code
OSHA	Occupational Safety and Health Administration
UPC	Uniform Plumbing Code

WC water closet

Glossary Terms in this Module:

“Agitated Water” means an AQUATIC VENUE with mechanical means (aquatic features) to discharge, spray, or move the water's surface above and/or below the static water line of the AQUATIC VENUE. Where there is no static water line, movement shall be considered above the deck plane.

“Aquatic Facility” means a physical place that contains one or more AQUATIC VENUES and support infrastructure under a single management structure.

“Aquatic Venue” means an artificially constructed or modified natural structure where the general public is exposed to water intended for recreational or therapeutic purpose. Such structures do not necessarily contain standing water, so water exposure may occur via contact, ingestion, or aerosolization. Examples include swimming pools, wave pool, rivers, spas (including spa pools and hot tubs), therapeutic pools, and spray pads/interactive water venues.

“Authority Having Jurisdiction” (AHJ) means an agency, organization, office, or individual responsible for enforcing the requirements of a code or standard, and/or for approving equipment, materials, an installation, or a procedure.

“Backflow” means a hydraulic condition caused by a difference in water pressure that causes non-potable water or other liquid to enter the potable water system by either backpressure or back-siphonage.

“Bather” means a person at an AQUATIC VENUE who has contact with water either through spray or partial or total immersion. The term Bather as defined, also includes staff members, and refers to those users who can be exposed to contaminated water as well as potentially contaminate the water.

“Bather Load” means the maximum number of persons allowed in the water of an AQUATIC VENUE. Bather load is used to determine the number of RINSE and CLEANSING SHOWERS. Bather Load is not the same as OCCUPANT LOAD which refers to maximum aquatic facility loads.

“Cleansing Shower” means a shower located within a HYGIENE FACILITY using warm water and soap. The purpose of these showers is to remove contaminants including perianal fecal material, sweat, skin cells, personal care products, and dirt before BATHERS enter the pool.

“Code” means a systematic statement of a body of law, especially one given statutory force.

“Deck”

- **“Perimeter Deck”** means the hardscape surface area immediately adjacent to and within 4 feet (1.22 m) of the edge of the swimming pool also known as the “wet deck” area.
- **“Pool Deck”** means surface areas serving the AQUATIC VENUE, beyond perimeter deck, which is expected to be regularly trafficked and made wet by BATHERS.

“Diaper-aged children” mean children less than 5 years of age.

“Diaper-changing station” means a hygiene station that includes a safe and approved DIAPER-CHANGING UNIT, adjacent hand-washing sink, soap and dispenser, hand drying device or paper towels and dispenser, and trash receptacle, and disinfectant products to clean the changing surface after use.

“Diaper-changing unit” means a safe and approved diaper-changing surface that is part of a DIAPER-CHANGING STATION.

“Flat Water” means an AQUATIC VENUE in which the water line is static except for movement made by users.

“Foot Bath” means standing water in which patrons or aquatics staff rinse their feet.

“Hand Wash Station” means a hand wash sink, adjacent soap with dispenser, hand drying device or paper towels and dispenser, and trash receptacle

“Hot Water” means an AQUATIC VENUE with a temperature over 90 degrees Fahrenheit (30 degrees Celsius).

“Hygiene Facility” means a structure or part of a structure that contains toilet, shower, DIAPER-CHANGING UNIT, HAND WASH STATION, and dressing capabilities serving BATHERS and patrons at an AQUATIC FACILITY.

“Hygiene Fixtures” means all components necessary for hygiene facilities including PLUMBING FIXTURES, DIAPER-CHANGING STATIONS, HAND WASH STATIONS, trashcans, soap dispensers, paper towel dispensers or hand dryers, and toilet paper dispensers.

“Occupant Load” means the combined total of the BATHER LOAD and the DRY DECK, POOL DECK, AND PERIMETER DECK surrounding the AQUATIC VENUE. OCCUPANT LOAD is used to determine the number of toilets, sinks, and diaper changing stations.

“Perimeter Deck” means the hardscape surface area immediately adjacent to and within 4 feet (1.22 m) of the edge of the swimming pool also known as the “wet deck” area.

“Plumbing Fixtures” means fixture or device for the distribution and use of water; for example, toilets, urinals, showers, and hose bibs.

“Pool Deck” means surface areas serving the AQUATIC VENUE, beyond perimeter deck, which is expected to be regularly trafficked and made wet by BATHERS.

“Rinse Shower” means a shower typically located in the POOL DECK area with ambient temperature water. The main purpose is to remove dirt, sand, or organic material prior to entering the AQUATIC VENUE.

“Sanitize” means reducing the level of microbes to that considered safe by public health standards. This may be achieved through a variety of chemical or physical means including chemical treatment, cleaning or drying.

“Substantial Renovation” means the renovation of a major component or substantial structural part of an aquatic venue that either:

- 1) Materially increases the value of the property,
- 2) Substantially prolongs the useful life of the venue, or
- 3) Adapts the venue to a new or better use.”

Preface: *This document does not address all safety concerns, if any, associated with its use. It is the responsibility of the user of this document to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to each use.*

Model Aquatic Health Code Hygiene Facilities Module

Keyword	Section	Code	Grade
	4.0	Design Standards and Construction	
	4.1	Plan Submittal	
	4.2	Materials	
	4.3	Equipment Standards	
	4.4	Pool Operation and Facility Maintenance	
	4.5	Pool Structure	
	4.6	Indoor/Outdoor Environment	
	4.7	Recirculation and Water Treatment	
	4.8	Decks and Equipment	
	4.9	Filter/Equipment Room	
	4.10	Hygiene Facilities	
<i>General</i>	4.10.1.	General	
<i>Required</i>	4.10.1.1	All design provisions shall be required for new construction or substantial renovation to an existing facility, except the following MAHC sections which shall be required for all aquatic facilities at time of adoption: <ol style="list-style-type: none"> 1) 4.10.4.5: DIAPER-CHANGING STATIONS, 2) 4.10.4.6.5: Soap Dispensers, and 3) 4.10.4.6.9: Trash Can 	
<i>Hygiene Facilities</i>	4.10.1.2	AQUATIC FACILITIES shall provide HYGIENE FACILITIES that include, at a minimum, toilets, urinals, showers, DIAPER-CHANGING STATIONS, and other HYGIENE FIXTURES, as specified herein.	
<i>Codes</i>	4.10.1.3	HYGIENE FACILITIES shall be constructed in accordance with applicable state and local CODES or as modified herein.	
<i>State & Local Code</i>	4.10.1.4	The minimum number of toilets, urinals, and other HYGIENE FIXTURES provided, excluding showers, shall be the greater of the following two options: <ol style="list-style-type: none"> 1) In accordance with applicable state and local CODES, or 2) Based upon maximum OCCUPANT LOAD of each 	

Keyword	Section	Code	Grade
		AQUATIC VENUE.	
Bather Load	4.10.1.5	BATHER LOAD shall be based on square footage of surface water or, if no standing water is present, the surface area of an AQUATIC VENUE.	
Square footage	4.10.1.5.1	BATHER LOAD for all AQUATIC VENUES shall be calculated as defined in MAHC Section 4.6.2.1.7 (see <i>Ventilation Module excerpt below</i>).	
		<i>The following section has been pulled from the MAHC Ventilation Module Section 4.6.2.1.7:</i>	
		FLAT WATER: 20 ft ² per BATHER.	
		<ul style="list-style-type: none"> Includes waterslides (runout area and exposed water as equivalent surface water), plunge pools, and aquatic venues without standing water (calculate the PERIMETER DECK area for BATHER LOAD) 	
		AGITATED WATER: 15 ft ² per BATHER	
		HOT WATER: 10 ft ² per BATHER	
Location	4.10.2	Location	
Distance	4.10.2.1	Except as required in 4.10.2.2, a drinking fountain, toilet, HAND WASH STATION, and DIAPER-CHANGING STATION shall be located no greater than 300 feet (91m) walking distance from each AQUATIC VENUE.	
Diaper-Aged Children	4.10.2.2	An AQUATIC VENUES designed primarily for use by DIAPER-AGED CHILDREN (children less than 5 years of age) shall have a drinking fountain, toilet, HAND WASH STATION, and DIAPER-CHANGING STATION located no greater than 200 feet (61m) walking distance and in clear view from the nearest entry/exit of the AQUATIC VENUE.	
Design & Construction	4.10.3	Design and Construction	
Floors	4.10.3.1	The floors of HYGIENE FACILITIES and dressing areas serving AQUATIC FACILITIES shall have a smooth, hard, easy-to-clean, impervious-to-water, slip-resistant	

Keyword	Section	Code	Grade
		surface.	
Floor Base	4.10.3.2	A hard, smooth, impervious-to-water, easy-to-clean base shall provide a sealed, coved juncture between the wall and floor and extend upward on the wall at least 6 inches (15cm).	
Floor Drains	4.10.3.3	Floor drains shall be installed in HYGIENE FACILITIES and dressing areas where PLUMBING FIXTURES are located.	
Opening Grill Covers	4.10.3.3.1	Floor drain opening grill covers shall be ½-inch (1cm) or less in width or diameter.	
Sloped to Drain	4.10.3.3.2	Floors shall be sloped to drain water or other liquids.	
ADAAG	4.10.3.3.3	Where deck areas serve as accessible routes or portions thereof, slopes in any direction shall not exceed ADAAG Guidelines and MAHC Sections 4.8.1.3.1.	
Partitions and Enclosures	4.10.3.4	Partitions and enclosures adjacent to HYGIENE FACILITIES shall have a smooth, easy-to-clean, impervious surface.	
Hose Bibb	4.10.3.5	At least one hose bibb or other potable water source capable of connecting a hose shall be located in each HYGIENE FACILITY to facilitate cleaning.	
Fixture Requirements	4.10.4	Plumbing Fixture Requirements	
General	4.10.4.1	General	
Protected	4.10.4.1.1	PLUMBING FIXTURES shall be installed and operated in a manner to adequately protect the potable water supply from back siphonage or BACKFLOW in accordance with local, state or federal regulation.”	
Easily Cleaned	4.10.4.1.2	PLUMBING FIXTURES shall be designed so that they may be readily and frequently cleaned, SANITIZED, and disinfected.	
Toilet Counts	4.10.4.1.3	Total toilet or urinal counts shall be in accordance with applicable state and local CODES or as modified herein.	

Keyword	Section	Code	Grade
Hand Wash Sink	4.10.4.1.4	Hand wash sink counts shall be in accordance with applicable state and local CODES or as modified herein.	
Cleansing Showers	4.10.4.2	Cleansing Showers	
Count	4.10.4.2.1	Total male and female CLEANSING SHOWER count shall be the greater of the following two options: <ul style="list-style-type: none"> 1) In accordance with applicable state and local CODES, or 2) Based on the BATHER LOAD of the AQUATIC VENUE. 	
Minimum	4.10.4.2.2	Minimum total CLEANSING SHOWER count shall be equal to 1 CLEANSING SHOWER 40 BATHERS for every AQUATIC FACILITY.	
Distributed	4.10.4.2.3	CLEANSING SHOWERS shall be evenly distributed between sexes, as applicable.	
Minimum	4.10.4.2.4	AQUATIC FACILITIES shall have a minimum of 1 CLEANSING SHOWER per sex.	
Location	4.10.4.2.5	CLEANSING SHOWERS shall be located in a HYGIENE FACILITY near the entrance and within clear view of the AQUATIC VENUE.	
Enclosed	4.10.4.2.6	Entryways to private or group CLEANSING SHOWER areas shall be enclosed by a door or curtain.	
Doors	4.10.4.2.6.1	Shower doors shall be of a smooth, hard, easy-to-clean material.	
Curtains	4.10.4.2.6.2	Shower curtains shall be of a smooth, easy-to-clean material.	
Soap	4.10.4.2.7	CLEANSING SHOWERS shall be supplied with soap and a soap dispenser adjacent to the shower.	
Exemption	4.10.4.2.8	AQUATIC VENUES located in lodging and residential settings shall be exempt from MAHC Section 4.10.4.2.	
Rinse Showers	4.10.4.3	Rinse Showers	
Minimum	4.10.4.3.1	A minimum of 1 RINSE SHOWER shall be provided on	

Keyword	Section	Code	Grade
		the deck near an entry point to the AQUATIC VENUE.	
Temperature	4.10.4.3.2	Water used for RINSE SHOWERS may be at ambient temperature	
Floor Sloped	4.10.4.3.3	Floors of RINSE SHOWERS shall be sloped to drain wastewater away from the AQUATIC VENUE and meet local applicable CODES.	
Large Facilities	4.10.4.3.4	Rinse showers in AQUATIC FACILITIES greater than 7500 square feet of water surface area shall be situated adjacent to each venue entry point or arranged to encourage BATHERS to use the RINSE SHOWER prior to entering the AQUATIC VENUE.	
Beach Entry	4.10.4.3.5	A minimum of 4 showerheads per 50 feet of beach entry AQUATIC VENUES shall be provided as a RINSE SHOWER.	
Leisure River	4.10.4.3.6	A minimum of 2 RINSE SHOWERS shall be provided at each entrance to a leisure river AQUATIC VENUE.	
Waterslide	4.10.4.3.7	A minimum of 1 RINSE SHOWER shall be provided at each entrance to a waterslide queue line.	
All Showers	4.10.4.4	All Showers	
Exceptions	4.10.4.4.1	AQUATIC FACILITIES with 7500 square feet of water area or more may be flexible in the number of CLEANSING SHOWERS they provide based on their BATHER LOAD: <ol style="list-style-type: none"> 1) 25% of the required showers shall be CLEANSING SHOWERS, 2) 25% of the required showers shall be RINSE SHOWERS, and 3) the remaining 50% may be either cleansing or RINSE SHOWERS. 	
Diaper-Changing Stations	4.10.4.5	Diaper-Changing Stations	
Each Facility	4.10.4.5.1	All aquatic facilities allowing use by diaper-aged BATHERS shall have at least one DIAPER-CHANGING STATION in each male and female HYGIENE FACILITY or make available a uni-sex DIAPER-CHANGING STATION.	

Keyword	Section	Code	Grade
Sink	4.10.4.5.2	The adjacent hand wash sink shall be installed and operational within 1 year from the date of the AHJ's adoption of the MAHC.	
Portable	4.10.4.5.3	If a hand sink is not available adjacent to the DIAPER-CHANGING STATION, a portable HAND-WASH STATION shall be available adjacent to the station at all times.	
Conform	4.10.4.5.4	DIAPER-CHANGING UNITS shall conform to either <ol style="list-style-type: none">1) ASTM standard F2285-04 "Consumer Performance Standards for Commercial Diaper-Changing Stations," or2) The standards for diaper-changing surfaces in the most current version of <i>Caring for Our Children: National Health and Safety Performance Standards: Guidelines for Out-of-Home Child Care Programs</i>.	
Signage	4.10.4.5.5	Signage shall be posted at DIAPER-CHANGING STATIONS stating: <ol style="list-style-type: none">1) Dispose of used disposable diapers in the diaper bucket or receptacle provided.2) Dump contents from reusable diapers into toilets and bag diapers to take home.3) Use the materials provided to clean/SANITIZE the surface of the DIAPER-CHANGING STATION before and after each use.4) Wash your hands and your child's hands after diapering.5) Do not swim if ill with diarrhea.	
Unisex	4.10.4.5.6	If only a unisex HYGIENE FACILITY is provided, it must have a DIAPER-CHANGING STATION that conforms to MAHC Section 4.10.4.5.	
Trash Can	4.10.4.5.7	A covered, hands-free, plastic-lined trash receptacle or diaper pail shall be located directly adjacent to the DIAPER-CHANGING UNIT.	

Keyword	Section	Code	Grade
Sanitizing Surface	4.10.4.5.8	An EPA-registered sanitizer shall be provided for maintaining a clean and SANITIZED DIAPER-CHANGING UNIT surface before and after each use.	
Non-Plumbing Fixtures	4.10.4.6	Non-Plumbing Fixture Requirements	
Easy to Clean	4.10.4.6.1	All HYGIENE FIXTURES and appurtenances in the dressing area shall have a smooth, hard, easy-to-clean, impervious-to-water surface and be installed to permit thorough cleaning.	
Glass	4.10.4.6.2	Glass, excluding mirrors, shall not be permitted in HYGIENE FACILITIES.	
Mirrors	4.10.4.6.3	Mirrors shall be shatter resistant.	
Lockers	4.10.4.6.4	If lockers are provided, they shall be set either on a solid base at least 6 inches (15cm) high or on legs at least 6 inches high and far enough apart to allow for cleaning and drying underneath the locker.	
Soap Dispensers	4.10.4.6.5	Soap dispensers shall be securely attached adjacent to hand-washing sinks and at each CLEANSING SHOWER.	
Dispenser Materials	4.10.4.6.5.1	The dispensers shall be of all metal, plastic or other shatterproof materials that can be readily and frequently cleaned.	
Dryers/Paper Towels	4.10.4.6.6	Hand dryers or paper towel dispensers shall be provided and securely attached adjacent to hand-washing sinks.	
Materials	4.10.4.6.6.1	Hand dryers and paper towel dispensers shall be of all metal, plastic or other shatterproof materials that can be readily and frequently cleaned.	
Toilet Paper Dispensers	4.10.4.6.7	Toilet paper dispensers shall be securely attached to wall or partition adjacent to each toilet.	
Female Facilities	4.10.4.6.8	In female HYGIENE FACILITIES, covered receptacles adjacent to each toilet shall be provided for disposal of used feminine hygiene products.	
Trash Can	4.10.4.6.9	A minimum of one hands-free trash receptacle shall be provided in areas adjacent to hand-washing sinks.	

Keyword	Section	Code	Grade
<i>Shared Equipment</i>	4.10.5	Provision of Suits, Towels, and Shared Equipment	
<i>Adequate Space</i>	4.10.5.1	Facilities supplying reusable suits, towels, and/or shared equipment shall provide adequate equipment and space for cleaning, sanitizing, drying, and storing of these materials.	
<i>Foot Baths</i>	4.10.6	Foot Baths	
<i>Prohibited</i>	4.10.6.1	FOOT BATHS shall be prohibited.	
<i>Sharps</i>	4.10.7	Sharps	
<i>Container</i>	4.10.7.1	If razors or other sharps are supplied by the facility, a sharps container approved by local, state or federal regulations shall be provided within the Hygiene facility.	
<i>Disposed</i>	4.10.7.2	Sharps within approved containers shall be disposed of as needed by the AQUATIC FACILITY in accordance with local, state, or federal regulations.	
<i>Biohazard Action Plan</i>	4.10.7.3	A biohazard action plan shall also be on file as required by local, state or federal regulations.	

Model Aquatic Health Code Hygiene Facilities Module

Keyword	Section	Code	Grade
	5.0	Operation and Maintenance	
	5.1	Plan Submittal	
	5.2	Materials	
	5.3	Equipment Standards	
	5.4	Pool Operation and Facility Maintenance	
	5.5	Pool Structure	
	5.6	Indoor/Outdoor Environment	
	5.7	Recirculation and Water Treatment	
	5.8	Decks and Equipment	
	5.9	Filter/Equipment Room	
<i>Hygiene Facilities</i>	5.10	Hygiene Facilities	
<i>General</i>	5.10.1	General	
<i>Location</i>	5.10.2	Location [N/A]	
<i>Bathhouse Design</i>	5.10.3	Design and Construction [N/A]	
<i>Fixture Requirements</i>	5.10.4	Plumbing Fixture Requirements	
<i>General Requirements</i>	5.10.4.1	General Requirements	
<i>Cleaned and Sanitized</i>	5.10.4.1.1	HYGIENE FACILITY fixtures, dressing area fixtures, and furniture shall be cleaned and SANITIZED daily and more often if necessary with an EPA-approved product and more often if necessary to provide a clean and sanitary environment.	
<i>Mold and Mildew</i>	5.10.4.1.2	HYGIENE FACILITY floors, walls, and ceilings shall be kept clean and free of visible mold and mildew.	
<i>Hand Wash Station</i>	5.10.4.1.3	HAND WASH STATIONS shall include the following items: <ol style="list-style-type: none"> 1) Hand wash sink, 2) Adjacent soap with dispenser, 3) Hand drying device or paper towels and dispenser, and 4) Trash receptacle. 	
<i>Showers</i>	5.10.4.2	Cleansing Showers	

Keyword	Section	Code	Grade
Cleaned and Sanitized	5.10.4.2.1	CLEANSING SHOWERS shall be cleaned and SANITIZED daily and more often if necessary with an EPA-approved product and more often if necessary to provide a clean and sanitary environment.	
Rinse Showers	5.10.4.3	Rinse Showers	
Cleaned	5.10.4.3.1	RINSE SHOWERS shall be cleaned daily and more often if necessary with an EPA-approved product and more often if necessary to provide a clean and sanitary environment.	
Easy Access	5.10.4.3.2	RINSE SHOWERS shall be easily accessible.	
Not Blocked	5.10.4.3.3	Equipment and furniture on the POOL DECK shall not block access to RINSE SHOWERS.	
No Soap	5.10.4.3.4	Soap dispensers and soap shall be prohibited at RINSE SHOWERS.	
All Showers	5.10.4.4	All Showers	
Diaper-Changing Stations	5.10.4.5	Diaper-Changing Stations	
Cleaned	5.10.4.5.1	DIAPER-CHANGING STATIONS shall be cleaned and SANITIZED daily and more often if necessary to provide a clean and sanitary environment.	
Maintained	5.10.4.5.1.1	They shall be kept in good condition and free of visible contamination.	
Sanitizer	5.10.4.5.2	EPA-registered sanitizer shall be provided in the form of the following: <ul style="list-style-type: none"> 1) A solution in a spray dispenser with paper towels and dispenser, or 2) Sanitizer wipes contained within a dispenser. 	
Covers	5.10.4.5.2.1	If disposable DIAPER-CHANGING UNIT covers are provided in addition to sanitizer, they shall cover the diaper changing unit surface during use and keep the unit in clean condition.	
Portable Hand	5.10.4.5.3	If a portable HAND WASH STATION is provided for use it	

Keyword	Section	Code	Grade
Wash Station		shall be operational and maintained in good condition at all times.	
Non-Plumbing Fixtures	5.10.4.6	Non-Plumbing Fixture Requirements	
Paper Towels	5.10.4.6.1	If paper towels are used for hand drying, a dispenser and paper towels shall be provided for use at HAND WASH STATIONS.	
Soap	5.10.4.6.2	Soap dispensers at HAND WASH STATIONS and CLEANSING SHOWERS shall be kept full of liquid or granular soap.	
Bar Soap	5.10.4.6.2.1	Bar soap shall be prohibited.	
Trash	5.10.4.6.3	Trash receptacles shall be emptied daily and more often if necessary to provide a clean and sanitary environment.	
Floor Coverings	5.10.4.6.4	Non-permanent floor coverings (including but not limited to mats and racks) shall be removable and maintained in accordance with MAHC section 5.10.4.1.1.	
Wood	5.10.4.6.4.1	Wooden racks, duckboards, and wooden mats are prohibited on HYGIENE FACILITY and dressing area flooring.	
Shared Equipment	5.10.5	Provision of Suits, Towels, and Shared Equipment	
Towels	5.10.5.1.	All towels provided by the AQUATIC FACILITY shall be washed with detergent in warm water, rinsed, and thoroughly dried after each use.	
	5.10.5.1.1	Towels shall be washed and thoroughly dried at the warmest temperature listed on the fabric label.	
Suits	5.10.5.1.2	Suits provided by the AQUATIC FACILITY shall be washed in accordance with the fabric label or manufacturer's instructions.	
Receptacles	5.10.5.2	Non-absorbent, easily cleanable receptacles shall be provided for collection of used suits and towels.	

Keyword	Section	Code	Grade
Shared Equipment-Contact	5.10.5.3	Equipment provided by the AQUATIC FACILITY that comes into contact with BATHER's eyes, nose, ears, and mouth <i>(including but not limited to snorkels, nose clips, and goggles)</i> shall be cleaned, SANITIZED, and stored in a manner to prevent biological growth.	
Other	5.10.5.4	Other shared equipment provided by the facility, including but not limited to fins, kickboards, tubes, and noodles, shall be cleaned, scrubbed, and stored in a manner to prevent biological growth.	
Good Repair	5.10.5.5	Shared equipment shall be maintained in good repair.	
Used Equipment	5.10.5.6	Used and unsanitized shared equipment shall be kept separate from cleaned and SANITIZED shared equipment.	
Receptacles	5.10.5.6.1	Non-absorbent, easily cleanable receptacles shall be provided for collection of used shared equipment.	
Foot Baths	5.10.6	Foot Baths	
Sharps	5.10.7	Sharps	