

Model Aquatic Health Code

Recirculation Systems and Filtration Module CODE Sections for the First 60-day Review

Posted for Public Comment on 07/02/2013

Currently Open for Public Comment that Closes on 08/31/2013

In an attempt to speed the review process along, the MAHC steering committee has decided to release MAHC draft modules prior to their being fully complete and formatted. These drafts will continue to be edited and revised while being posted for public comment. The complete versions of the drafts will also be available for public comment again when all MAHC modules are posted for final public comment. The MAHC committees appreciate your patience with the review process and commitment to this endeavor as we all seek to produce the best aquatic health code possible.

This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy.

MAHC Recirculation Systems and Filtration Module Abstract

Health issues related to waterborne diseases as well as exposure to chemicals associated with pool water are increasingly being documented. The Recirculation Systems and Filtration Module is a first step towards improving water quality at aquatic facilities and reducing associated health effects. The Recirculation Systems and Filtration Module contains design and construction requirements that are, unless otherwise specified, applicable only for new or modified construction. New and improved elements include:

- 1) More aggressive turnover times and more uniform standards for recirculation system design and operation.
- 2) Filter design and operation standards that will promote more effective and efficient filtration.
- 3) Requiring water replenishment to dilute out the dissolved contaminants that cannot be removed by pool filters.
- 4) Development of a long-term plan to use pool filters for pathogen removal in addition to water clarity in a multiple barrier system that would complement all disinfection processes.
- 5) Use of improved flow meters

MAHC Recirculation Systems and Filtration Module Review Guidance

The [Model Aquatic Health Code \(MAHC\) Steering](http://www.cdc.gov/healthywater/swimming/pools/mahc/steering-committee/) (<http://www.cdc.gov/healthywater/swimming/pools/mahc/steering-committee/>) and [Technical](http://www.cdc.gov/healthywater/swimming/pools/mahc/technical-committee/) (<http://www.cdc.gov/healthywater/swimming/pools/mahc/technical-committee/>) **Committees** appreciate your willingness to review this draft MAHC module. Your unique perspectives and science-based suggestions will help ensure that the best available standards and practices for protecting aquatic public health are available for adoption by state and local environmental health programs.

Review Reminders:

- Please download and use the [MAHC Comment Form](http://www.cdc.gov/healthywater/swimming/pools/mahc/structure-content/) (<http://www.cdc.gov/healthywater/swimming/pools/mahc/structure-content/>) to submit your detailed, succinct comments and suggested edits. Return your review form by 08/31/2013, as an email attachment to MAHC@cdc.gov.
- If part of a larger group or organization, please consolidate comments to speed the MAHC response time to public comments.
- To provide context for this module review, please consult the [MAHC Strawman Outline](http://www.cdc.gov/healthywater/pdf/swimming/pools/mahc/structure-content/mahc-strawman.pdf) (<http://www.cdc.gov/healthywater/pdf/swimming/pools/mahc/structure-content/mahc-strawman.pdf>). Section headers of related content have been included in this draft module to assist reviewers to see where each section fits into the overall MAHC structure. Additional MAHC draft modules that contain this content will be or already have been posted for your review.
- The complete draft MAHC, with all of the individual module review comments addressed will be posted again for a final review and comment before MAHC publication. This will enable reviewers to review modules in the context of other modules and sections that may not have been possible during the initial individual module review.

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

- The published MAHC will be regularly updated through a collaborative all-stakeholder process.

Please address any questions you may have about MAHC or the review process to MAHC@cdc.gov. You may also request to be on the direct email list for alerts (“Get Email Updates” is in a box on the right hand side of the Healthy Swimming website at www.cdc.gov/healthyswimming) on the other draft MAHC modules as they are released for public comment.

Thank you again, and we look forward to your help in this endeavor.
Sincerely,

Douglas C. Sackett, Director
MAHC Steering Committee

The Recirculation Systems and Filtration Code Module shows a Table of Contents giving the context of the Recirculation Systems and Filtration Design, Construction, Operation and Maintenance in the overall Model Aquatic Health Code’s Strawman Outline (<http://www.cdc.gov/healthywater/pdf/swimming/pools/mahc/structure-content/mahc-strawman.pdf>).

Reviewer Note on Module Section Numbering:

Please use the specific section numbers to make your comments on this Draft Model Aquatic Health Code module. These numbers may eventually change during the editing of the compiled Draft that will be issued for a final round of comments.

MAHC “Strawman”

Table of Contents (4.0 – 6.0 show proposed structure)

1.0	Preface
2.0	User Guide
3.0	Definitions
4.0	Design Standards and Construction
5.0	Operation and Maintenance
6.0	Policies and Management
7.0	Index
8.0	Annexes
9.0	Summary of Changes

4.0 Design Standards and Construction

4.1	Plan Submittal
4.2	Materials
4.3	Equipment Standards
4.4	Pool Operation and Facility Maintenance [N/A]

“This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy.”

- 4.5 Pool Structure (Shell)
- 4.6 Indoor/Outdoor Environment
- 4.7 Recirculation and Water Treatment
- 4.8 Decks and Equipment
- 4.9 Filter/Equipment Room
- 4.10 Hygiene Facilities (Bathhouse)
- 4.11 Water Supply/Wastewater Disposal
- 4.12 Specific Venues - Special Requirements

4.7 Recirculation and Water Treatment

4.7.1 Recirculation Systems and Equipment

4.7.1.1 General

4.7.1.2 Combined Venue Treatment

4.7.1.3 Inlets

4.7.1.3.1 General

4.7.1.3.2 Floor Inlets

4.7.1.3.3 Wall Inlets

4.7.1.4 Overflow Systems/Gutters

4.7.1.4.1 General

4.7.1.4.2 Gutter Size and Shape

4.7.1.4.3 Gutter Outlets

4.7.1.4.4 Surge or Balance Tank Capacity

4.7.1.4.5 Tolerances

4.7.1.4.6 Makeup Water System

4.7.1.5 Skimmers and Alternative Gutter Technologies Using In-pool Surge Capacity

4.7.1.5.1 General

4.7.1.5.2 Skimmer Location

4.7.1.5.3 Skimmer Flow Rate

4.7.1.5.4 Control

4.7.1.5.5 Tolerances

4.7.1.5.6 Testing

4.7.1.6 Submerged Suction Outlet

4.7.1.6.1 General

4.7.1.6.2 Number and Spacing

4.7.1.6.3 Tank Connection

4.7.1.6.4 Flow Distribution and Control

4.7.1.6.5 Flow Velocities

4.7.1.7 Piping

4.7.1.7.1 Design

4.7.1.7.2 Velocity in Pipes

4.7.1.7.3 Drainage and Installation

4.7.1.7.4 Piping and Component Identification

4.7.1.7.5 Testing

4.7.1.8 Strainers and Pumps

4.7.1.8.1 Strainers

4.7.1.8.2 Pumping Equipment

- 4.7.1.8.3 **Operating Gauges**
- 4.7.1.9 **Flow Measurement and Control**
- 4.7.1.10 **Flow Rates/Turnover**

4.7.2 Filtration

- 4.7.2.1 **Granular Media Filters**
 - 4.7.2.1.1 **General**
 - 4.7.2.1.2 **Filter Location and Spacing**
 - 4.7.2.1.3 **Filtration and Backwashing Rates**
 - 4.7.2.1.4 **Filter Media Depth Requirements**
 - 4.7.2.1.5 **Differential Pressure Measurement**
 - 4.7.2.1.6 **Coagulant injection Equipment**
- 4.7.2.2 **Precoat Filters**
 - 4.7.2.2.1 **General**
 - 4.7.2.2.2 **Filtration Rates**
 - 4.7.2.2.3 **Precoat Media Introduction System**
 - 4.7.2.2.4 **Continuous Filter Media Feed Equipment**
- 4.7.2.3 **Cartridge Filters**

4.7.3 Disinfection

- 4.7.3.1 **Chemical Addition Methods**
- 4.7.3.2 **Feed Equipment**
 - 4.7.3.2.1 **General**
 - 4.7.3.2.2 **Sizing of Disinfection Equipment**
 - 4.7.3.2.3 **Feeder Engineering**
 - 4.7.3.2.4 **Introduction of Chemicals**
 - 4.7.3.2.5 **Feeder Controls**
 - 4.7.3.2.6 **Compressed Chlorine Gas**
 - 4.7.3.2.7 **Types of Feeders**
 - 4.7.3.2.8 **Salt Electrolytic Chlorine Generators, Brine Electrolytic Chlorine, or Bromine Generators**
 - 4.7.3.2.9 **Feeders for pH Adjustment**
 - 4.7.3.2.10 **Controllers**

4.7.4 Water Disposal and Replenishment System

4.7.5 Spas

- 4.7.5.1 **General**
- 4.7.5.2 **Filtration System Inlets**
- 4.7.5.3 **Jet System Inlets**

- 5.0 **Operation and Maintenance**
- 5.1 **Plan Submittal [N/A]**
- 5.2 **Materials [N/A]**
- 5.3 **Equipment Standards [N/A]**
- 5.4 **Pool Operation and Facility Maintenance**
- 5.5 **Pool Structure (Shell)**

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

- 5.6 Indoor/Outdoor Environment
- 5.7 Recirculation and Water Treatment
- 5.8 Decks and Equipment
- 5.9 Filter/Equipment Room
- 5.10 Hygiene Facilities (Bathhouse)
- 5.11 Water Supply/Wastewater Disposal
- 5.12 Specific Venues - Special Requirements

5.7 Recirculation and Water Treatment

5.7.1 Recirculation Systems and Equipment

- 5.7.1.1 General**
- 5.7.1.2 Combined Venue Treatment**
- 5.7.1.3 Inlets
- 5.7.1.4 Surface Skimming Devices**
- 5.7.1.5 Submerged Drains/Suction Outlet Covers or Gratings**
- 5.7.1.6 Piping
- 5.7.1.7 Strainers and Pumps**
- 5.7.1.8 Flow Meters**
- 5.7.1.9 Flow Rates/Turnover

5.7.2 Filtration

- 5.7.2.1 Granular Media Filters**
- 5.7.2.2 Precoat Filters**
- 5.7.2.3 Cartridge Filters**

5.7.3 Disinfection

- 5.7.3.1 Chemical Addition Methods**
- 5.7.3.2 Feed Equipment
 - 5.7.3.2.1 General
 - 5.7.3.2.2 Sizing of Disinfection Equipment
 - 5.7.3.2.3 Feeder Engineering
 - 5.7.3.2.4 Introduction of Chemicals
 - 5.7.3.2.5 Feeder Controls
 - 5.7.3.2.6 Compressed Chlorine Gas
 - 5.7.3.2.7 Types of Feeders**
 - 5.7.3.2.8 Salt Electrolytic Chlorine Generators, Brine Electrolytic Chlorine, or Bromine Generators**
 - 5.7.3.2.9 Feeders for pH Adjustment
 - 5.7.3.2.10 Controllers

5.7.4 Water Disposal and Replenishment System

5.7.5 Spas

Acronyms in this Module:

- AHJ authority having jurisdiction
- ANSI American National Standards Institute
- ASME American Society of Mechanical Engineers

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

GPM	gallons per minute
MAHC	Model Aquatic Health Code
MSBL	maximum sustainable bather load
NPSH	net positive suction head
NRTL	Nationally Recognized Testing Laboratory
NSF	National Sanitation Foundation
TDS	total dissolved solids
UV	Ultraviolet
VFD	variable frequency drive

Glossary Terms in this Module:

“Aquatic Facility” means a physical place that contains one or more aquatic venues and support infrastructure under a single management structure.

“Aquatic Venue” means an artificially constructed or modified natural structure where the general public is exposed to water intended for recreational or therapeutic purpose. Such structures do not necessarily contain standing water, so water exposure may occur via contact, ingestion, or aerosolization. Examples include swimming pools, wave pool, river, spas (including spa pools and hot tubs), therapeutic pools, and spray pads/interactive water venues.

“Authority Having Jurisdiction” (AHJ) means an agency, organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

“Backflow” means a hydraulic condition caused by a difference in water pressure that causes non-potable water or other liquid to enter the potable water system by either backpressure or back-siphonage.

“Bather” means a person at an aquatic venue who has contact with water either through spray or partial or total immersion. The term Bather as defined, also includes staff members, and refers to those users who can be exposed to contaminated water as well as potentially contaminate the water.

“Chlorine” means an element that at room temperature and pressure is a heavy green gas with characteristic odor and is extremely toxic. It can be compressed in liquid form and stored in heavy steel tanks, but most pools now add other chlorine compounds (e.g. hypochlorite) that similar to the liquid form release hypochlorous acid when dissolved in water. Chlorinating agents are the most commonly used disinfectants for aquatic venues.

“Contaminant” means a substance that soils, stains, corrupts, or infects another substance by contact or association.

“Deck” means surface areas serving the pool, beyond perimeter deck, which is expected to be regularly trafficked and made wet by pool users.

“Disinfection” means a treatment that kills microorganisms (e.g., bacteria, viruses, and parasites); in water treatment, a chemical (commonly chlorine, chloramine, or ozone) or physical process (e.g., ultraviolet radiation) can be used.

“Hydraulically balanced” means both the relative difference between the water flow over the gutter or through the skimmers compared with the water flow through the main drain; and the even distribution of treated water returned to different areas of the pool through the inlets.

“Increased Risk Aquatic Venue” means an aquatic venue which due to its intrinsic characteristics and intended users has a greater likelihood of affecting the health and safety of the patrons of that venue by being at increased risk for contamination (e.g., by diaper-aged children/children aged <5 years old) or being used by people that may be more susceptible to infection (e.g., therapy patients with open wounds). Examples of increased-risk aquatic venues include spray pads, wading pools and other aquatic venues designed for diaper-aged children as well as therapy pools.

“Inlets” mean wall or floor fittings where treated water is returned to the pool.

“Monitoring” is the regular and purposeful observation and checking of systems or facilities and recording of data, including system alerts, excursions from acceptable ranges, and other facility issues. Monitoring includes human or electronic means.

“Perimeter Gutter System” means the alternative to skimmers as a method to remove water from the pool’s surface for treatment. The gutter provides a level structure along the pool perimeter versus the intermittent skimmers.

“pH” means a symbol that expresses the negative log of the concentration of hydrogen ions. When water ionizes, it produces hydrogen ions (H+) and hydroxide ions (OH-). If there is an excess of hydrogen ions the water is acidic. If there is an excess of hydroxide ions the water is basic. pH ranges from 0 to 14. Pure water has a pH of 7.0. If pH is higher than 7.0, the water is said to be basic, or alkaline. If the water’s pH is lower than 7.0, the water is acidic. As pH is raised, more ionization occurs and chlorine disinfectants decrease in effectiveness.

“Pool” means a subset of aquatic venue designed to have impounded/standing water for total or partial bather immersion.

“Sanitize” means reducing the level of microbes to that considered safe by public health standards. This may be achieved through a variety of chemical or physical means including chemical treatment, cleaning or drying.

“Secondary disinfection systems” means those disinfection processes (e.g., UV, ozone) which are required in certain circumstances to meet the minimum standards of this code and are in addition to the requirements of Section 5.0 of this code.

“Spa” means a structure that is intended to be used for bathing or other recreational uses and is not drained and refilled after each use. It may include, but is not limited to, hydrotherapy, air induction bubbles, and recirculation.

“This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy.”

“Spray Pad” means no standing water, features included that spray bathers with recirculating water.

“Supplemental disinfection systems” means those disinfection processes or systems which are optional and not required on an aquatic venue for health and safety reasons. They may be used to enhance overall system performance.

“Surge Tank Net Capacity” means the total tank capacity minus the volume of the tank that is filled when the pool is unoccupied.

“Recirculation System” means the combination of the main drain, gutter or skimmer, inlets, piping, pumps, controls, surge tank or balance tank to provide pool water recirculation to and from the pool and the treatment systems.

“Skimmer System” means periodic locations along the top of the pool wall for removal of water from the pool’s surface for treatment.

“Water Replenishment System” means a way to remove water from the pool as needed and replace with make-up water to maintain water quality.

***Preface:** This document does not address all health and safety concerns, if any, associated with its use. It is the responsibility of the user of this document to establish appropriate health and safety practices and determine the applicability of regulatory limitations prior to each use.*

Model Aquatic Health Code
Recirculation Systems and Filtration Module Code
4.0 Design and Construction

Keyword	Section	Code	Grade
	4.0	Design Standards and Construction	
	4.1	Plan Submittal	
	4.2	Materials	
	4.3	Equipment Standards	
	4.4	Pool Operation and Facility Maintenance	
	4.5	Pool Structure	
	4.6	Indoor/Outdoor Environment	
	4.7	Recirculation and Water Treatment	
<i>Recirculation Systems</i>	4.7.1	Recirculation Systems and Equipment	
<i>General</i>	4.7.1.1	General	
<i>Equipped and Operated</i>	4.7.1.1.1	All AQUATIC FACILITIES shall be equipped and operated with a recirculation and filtration system capable of meeting the provisions outlined in MAHC Section 4.7.	
<i>Component Installation</i>	4.7.1.1.2	The installation of the recirculation and the filtration system components shall be performed in accordance with the designer's and manufacturers' instructions.	
<i>Recirculation System</i>	4.7.1.1.3	A water RECIRCULATION SYSTEM consisting of one or more pumps, pipes, return INLETS, suction outlets, filters, and other necessary equipment shall be provided.	
<i>Combined Aquatic Venue Treatment</i>	4.7.1.2	Combined Aquatic Venue Treatment	
<i>Maintain and Measure</i>	4.7.1.2.1	When treatment systems of aquatic venues are combined, the design shall include all appurtenances to maintain and measure the required water characteristics including but not limited to flow rate, PH, and disinfectant concentration in each venue/feature.	
<i>Secondary Disinfection</i>	4.7.1.2.2	If SECONDARY DISINFECTION is required for an INCREASED RISK AQUATIC VENUE/FEATURE as per MAHC Section 4.7.3.3.1.2, then SECONDARY DISINFECTION shall be required for all treatment systems that are combined with the INCREASED RISK AQUATIC VENUE/FEATURE.	

Note: Please see language inserted below, taken from MAHC Disinfection and Water Quality Draft Guidance, MAHC Code Section 4.7.3.3.1.2:

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
		<p>The new construction or substantial renovation of the following INCREASED RISK AQUATIC VENUES shall be required to use a SECONDARY DISINFECTION SYSTEM after adoption of this CODE:</p>	
		<ol style="list-style-type: none"> 1) AQUATIC VENUES designed primarily for diaper-aged children (children <5 years old), such as <ol style="list-style-type: none"> a. wading AQUATIC VENUES, b. water activity AQUATIC VENUES, c. interactive water features with no standing water, and 2) Therapy pools. 	
<i>Isolate</i>	4.7.1.2.3	Each component of a combined venue treatment system shall be capable of being isolated for maintenance purposes.	
<i>Inlets</i>	4.7.1.3	<i>Inlets</i>	
<i>General</i>	4.7.1.3.1	<i>General</i>	
<i>Hydraulically Balanced</i>	4.7.1.3.1.1	<p>The RECIRCULATION SYSTEM shall be designed with sufficient flexibility to achieve a HYDRAULIC BALANCE that will ensure the following:</p> <ol style="list-style-type: none"> 1) Effective distribution of treated water, and 2) Maintenance of a uniform disinfectant residual and pH throughout the AQUATIC VENUE. 	
<i>Alternative Design Justification</i>	4.7.1.3.1.1.1	Alternative designs shall be allowed based on adequate engineering justification.	
<i>Continuous Perimeter Gutter System</i>	4.7.1.3.1.2	This shall be accomplished by either a continuous PERIMETER GUTTER system with integral INLETS or by means of adjustable INLETS adequate in design, number, and location.	
<i>Adequate mixing</i>	4.7.1.3.1.3	POOLS shall use wall and/or floor INLETS to provide adequate mixing.	
<i>Other Inlet Types</i>	4.7.1.3.1.4	All other types of INLET systems not covered in this section shall be subject to approval by the AHJ with proper engineering justification.	
<i>Hydraulically Sized</i>	4.7.1.3.1.5	INLETS shall be hydraulically sized to provide the design flow rates for each POOL area of multi-zone pools based on the required design turnover rate for each zone.	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
<i>Floor Inlets</i>	4.7.1.3.2	<i>Floor Inlets</i>	
<i>Uniformly Spaced</i>	4.7.1.3.2.1	Floor INLETS shall be uniformly spaced and flush with the bottom of the POOL.	
<i>Distance</i>	4.7.1.3.2.1.1	Distance between floor INLETS shall be no greater than 20 feet (6.1 m).	
<i>Row</i>	4.7.1.3.2.1.2	Rows of INLETS shall be within 15 feet (4.6 m) of each side.	
<i>Spaced</i>	4.7.1.3.2.2	Floor INLETS, used in combination with wall INLETS, shall be spaced no greater than 25 feet (7.6 m) from adjacent side walls.	
<i>Wall Inlets</i>	4.7.1.3.3	<i>Wall Inlets</i>	
<i>Additional Recirculation</i>	4.7.1.3.3.1	Additional low level recirculation shall be provided for areas deeper than 10 feet.	
<i>Effective Mixing</i>	4.7.1.3.3.2	Wall INLET velocity shall mix the water effectively.	
<i>Adjustable</i>	4.7.1.3.3.3	INLETS shall be directionally adjustable.	
<i>Inlet Spacing</i>	4.7.1.3.3.4	Wall INLETS shall be spaced no greater than 20 feet (6.1 m) apart.	
<i>Corner</i>	4.7.1.3.3.4.1	INLETS shall be placed within 5 feet (1.5 m) of each corner of the POOL.	
<i>Isolated</i>	4.7.1.3.3.4.2	INLETS shall be placed in each recessed or isolated area of the POOL.	
<i>Directional Flow</i>	4.7.1.3.3.5	Wall INLETS that are not part of a manufactured gutter system shall be designed to provide directional flow.	
<i>Dye Testing</i>	4.7.1.3.3.6	Dye testing shall be required to evaluate the mixing characteristics of the RECIRCULATION SYSTEM unless exempted by the local AHJ.	
<i>Testing Methods</i>	4.7.1.3.3.6.1	Dye testing methods to meet this requirement are in Appendix 1.	
<i>Failed Test</i>	4.7.1.3.3.6.2	If dye test reveals inadequate mixing in the POOL after 15-20 minutes, the RECIRCULATION SYSTEM shall be modified to assure adequate mixing.	
<i>Overflow Systems</i>	4.7.1.4	<i>Overflow Systems/Gutters</i>	
<i>General</i>	4.7.1.4.1	<i>General</i>	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
Skimming	4.7.1.4.1.1	All POOLS shall be designed to provide SKIMMING for the entire POOL surface area with engineering rationale provided by the design professional.	
Zero-depth Entry	4.7.1.4.1.2	Zero-depth entry POOLS shall have a continuous overflow trench that terminates as close to the side walls as practical.	
Size and Shape	4.7.1.4.2	<i>Gutter Size and Shape</i>	
Continuous Water Removal	4.7.1.4.2.1	The gutter system shall be designed to allow continuous removal of water from the POOL's upper surface at a rate of at least 125 percent of the approved total recirculation flow rate chosen by the designer.	
Inspection	4.7.1.4.2.2	Gutters shall permit ready inspection, cleaning, and repair.	
Outlets	4.7.1.4.3	<i>Gutter Outlets</i>	
Design Capacity	4.7.1.4.3.1	Drop boxes, converters, return piping, or flumes used to convey water from the gutter shall be designed to handle at least 125 percent of the approved total recirculation flow.	
Drainage	4.7.1.4.3.2	Drainage shall be sized to prevent flooding and BACKFLOW of skimmed water into the POOL.	
Surge Capacity	4.7.1.4.4	<i>Surge Tank Capacity</i>	
Net Surge Capacity	4.7.1.4.4.1	All overflow systems shall be designed with an effective net surge tank capacity of not less than 1 gallon for each square foot (41 L/m ²) of POOL surface area.	
Tank Capacity	4.7.1.4.4.2	The tank capacity specified shall be the net capacity	
Tank Levels	4.7.1.4.4.3	The design professional shall define the surge tank's minimum, maximum, and unoccupied POOL levels in the surge tank.	
Marked	4.7.1.4.4.3.1	The surge tank's minimum, maximum, and unoccupied POOL levels shall be marked on the tank.	
Overflow Pipes	4.7.1.4.4.4	Surge tanks, shall have overflow pipes to convey excess water to waste via an air gap or other approved BACKFLOW prevention device.	
Tolerances	4.7.1.4.5	<i>Tolerances</i>	
Venue Perimeter	4.7.1.4.5.1	Gutters shall be level within a tolerance of plus or minus 1/8 inch	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
		(3.175 mm) around the perimeter of the AQUATIC VENUE.	
Makeup Water	4.7.1.4.6	<i>Makeup Water System</i>	
Automatic	4.7.1.4.6.1	Automatic makeup water supply equipment shall be provided to maintain continuous skimming of all POOLS.	
Air Gap	4.7.1.4.6.2	Makeup water shall be supplied through an air gap or other approved BACKFLOW prevention device.	
Skimmers	4.7.1.5	<i>Skimmers and Alternative Gutter Technologies Using In-pool Surge Capacity</i>	
General	4.7.1.5.1	<i>General</i>	
Manufactured	4.7.1.5.1.1	The use of manufactured direct suction skimmers shall be in accordance with the manufacturer's recommendations and NSF Standard 50 certification of each skimmer.	
Provided	4.7.1.5.1.2	At least one surface skimmer shall be provided for each 500 square feet (46 m ²) of surface area or fraction thereof.	
Conditions	4.7.1.5.1.2.1	Additional skimmers may be required to achieve effective skimming under site-specific conditions (e.g., <i>heavy winds and/or CONTAMINANT loading</i>) and/or to comply with all applicable building codes.	
Hybrid Systems	4.7.1.5.1.3	Hybrid systems that can switch between skimmers and overflow gutters through the use of in-POOL surge shall meet all of the requirements specified for each system (<i>with the exception of the surge or balance tank since the surge capacity requirement will be alternately met by the in-POOL surge capacity</i>).	
Number	4.7.1.5.1.4	At least two skimmers shall be provided to reduce the impact of prevailing winds on removing CONTAMINANTS from the surface of the POOL.	
Design Capacity	4.7.1.5.1.5	The SKIMMER SYSTEM, when used, shall be designed to handle up to 100% of the total recirculation flow rate chosen by the designer.	
Pool Width Limitations	4.7.1.5.1.6	POOLS using skimmers shall not exceed 30 feet (9.1 m) in width.	
Location	4.7.1.5.2	<i>Skimmer Location</i>	
Effective	4.7.1.5.2.1	Skimmers shall be so located as to provide effective skimming of the entire water surface.	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
Steps and Recessed areas	4.7.1.5.2.2	Skimmers shall be offset from steps and recessed areas.	
Wind Direction	4.7.1.5.2.3	Wind direction shall be considered in skimmer placement.	
Flow Rate	4.7.1.5.3	<i>Skimmer Flow Rate</i>	
NSF 50	4.7.1.5.3.1	The flow rate for the skimmers shall comply with manufacturer data plates or ANSI NSF Standard 50 including Annex K.	
Control	4.7.1.5.4	<i>Control</i>	
Weir	4.7.1.5.4.1	Each skimmer shall have a weir that adjusts automatically to variations in water level of at least 4 inches (10 cm).	
Trimmer Valve	4.7.1.5.4.2	Each skimmer shall be equipped with a trimmer valve capable of distributing the total flow between individual skimmers.	
Tolerances	4.7.1.5.5	<i>Tolerances</i>	
Skimmer Base	4.7.1.5.5.1	The base of each skimmer shall be level within a tolerance of plus or minus ¼ inch (6 mm).	
Testing	4.7.1.5.6	<i>Testing</i>	
Flotation Tests	4.7.1.5.6.1	Flotation tests should be performed annually to ensure effective skimming and proper adjustment of flow distribution between skimmers.	
Submerged Suction	4.7.1.6	<i>Submerged Suction Outlet</i>	
General	4.7.1.6.1	<i>General</i>	
Conform	4.7.1.6.1.1	Submerged suction outlets, including sumps and covers, shall conform to the requirements of ASME/ANSI A112.19.8.	
Number and Spacing	4.7.1.6.2	<i>Number and Spacing</i>	
Hydraulically Balanced	4.7.1.6.2.1	A minimum of two HYDRAULICALLY BALANCED outlets are required in the bottom at the deepest level.	
Spaced	4.7.1.6.2.2	Outlets shall be equally spaced from the POOL side walls.	
Located	4.7.1.6.2.3	Outlets shall be located no less than 6 feet (1.8 m) apart, measuring between the centerlines of the drain covers.	

Keyword	Section	Code	Grade
Tank Connection	4.7.1.6.3	<i>Tank Connection</i>	
Gravity Drains	4.7.1.6.3.1	Where gravity drains are used, the main drain outlet shall be connected to a surge tank or balance tank/pipe.	
Flow Control	4.7.1.6.4	<i>Flow Distribution and Control</i>	
Design Capacity	4.7.1.6.4.1	The main drain system shall be designed at a minimum to handle recirculation flow of 100% of total design recirculation flow rate if a single main drain is blocked.	
Proportioning Valve	4.7.1.6.4.2	The main drain system shall be equipped with a proportioning valve(s) to adjust the flow distribution between the main drain piping and the surface overflow system piping.	
Flow Velocities	4.7.1.6.5	<i>Flow Velocities</i>	
Standards	4.7.1.6.5.1	Flow velocities shall meet ANSI/APSP-16 2011 based on 100% design flow through each main drain cover.	
Piping	4.7.1.7	<i>Piping</i>	
Design	4.7.1.7.1	<i>Design</i>	
Accepted Practice	4.7.1.7.1.1	RECIRCULATION SYSTEM piping shall be designed according to accepted engineering practices.	
Materials	4.7.1.7.1.2	Piping system components in contact with swimming POOL water shall be of non-toxic material, resistant to corrosion, able to withstand operating pressures, chemicals, and temperatures.	
Standards	4.7.1.7.1.3	Piping materials shall be suitable for potable water contact and shall meet NSF/ANSI Standard 61 and NSF/ANSI Standard 14 as applicable.	
Velocity	4.7.1.7.2	<i>Velocity in Pipes</i>	
Discharge Piping	4.7.1.7.2.1	RECIRCULATION SYSTEM piping shall be designed so that water velocities do not exceed 8 feet (2.4 m) per second on the discharge side of the recirculation pump unless alternative values have proper engineering justification.	
Gravity Piping	4.7.1.7.2.2	Gravity piping shall be sized with velocity of no less than 2 feet (0.6 m) per second to prevent particles settling inside pipes.	
Additional Considerations	4.7.1.7.2.2.1	Gravity piping shall be sized with consideration of available	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
		system head or as demonstrated by detailed hydraulic calculations at the design recirculation flow rate.	
<i>Drainage and Installation</i>	4.7.1.7.3	<i>Drainage and Installation</i>	
<i>Temperature Variations</i>	4.7.1.7.3.1	Provisions shall be made for expansion and contraction of pipes due to temperature variations.	
<i>Gravity Drainage</i>	4.7.1.7.3.2	Provisions shall be made for gravity drainage of all POOL piping exposed to a freezing climate.	
<i>Supported</i>	4.7.1.7.3.3	All piping shall be supported continuously or at sufficiently close intervals to prevent sagging and settlement.	
<i>Temperature Provisions</i>	4.7.1.7.3.4	Provisions shall be made for expansion and contraction of pipes due to temperature variations.	
<i>Component Identification</i>	4.7.1.7.4	<i>Piping and Component Identification</i>	
<i>Clearly Marked</i>	4.7.1.7.4.1	All exposed piping shall be clearly marked to indicate function.	
<i>Flow Direction and Source</i>	4.7.1.7.4.2	Pipes shall be marked to indicate flow direction and source.	
<i>Valves</i>	4.7.1.7.4.3	All valves shall be clearly marked to indicate function by using color coding or detail labeling.	
<i>Schematic Displayed</i>	4.7.1.7.4.4	A complete easily readable schematic of the entire POOL RECIRCULATION SYSTEM shall be openly displayed in the mechanical room or available to maintenance or inspection personnel.	
<i>Testing</i>	4.7.1.7.5	<i>Testing</i>	
<i>Static Hydraulic Pressure Test</i>	4.7.1.7.5.1	New and renovated suction and supply POOL piping shall be subjected to an induced static hydraulic pressure test for 6 hours.	
<i>Greater</i>	4.7.1.7.5.2	New and renovated suction and supply POOL piping shall be able to maintain the greater of the two following amounts of pressure: <ol style="list-style-type: none"> 1) 25% greater than the maximum design operating pressure of the system, or 2) 25 psi (172 KPa). 	
<i>Strainers and Pumps</i>	4.7.1.8	<i>Strainers and Pumps</i>	
<i>Strainers</i>	4.7.1.8.1	<i>Strainers</i>	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
Strainer / Screen	4.7.1.8.1.1	All filter recirculation pumps shall have a strainer/screen device on the suction side to protect the filtration and pumping equipment.	
Materials	4.7.1.8.1.2	All material used in the construction of strainers and screens shall be: <ol style="list-style-type: none"> 1) Nontoxic, impervious, and enduring, 2) Able to withstand design stresses, and 3) Designed to minimize friction losses 	
Pumps	4.7.1.8.2	<i>Pumping Equipment</i>	
Variable Frequency Drives	4.7.1.8.2.1	Variable frequency drives (VFDs) may be installed to control all recirculation and feature pumps.	
Total Dynamic Head	4.7.1.8.2.2	The recirculation pump(s) shall be selected to provide the required recirculation flow in accordance with the maximum total dynamic head required by the entire RECIRCULATION SYSTEM under the most extreme operating conditions (e.g., clogged filters in need of backwashing).	
Required Flow Rate	4.7.1.8.2.3	The pump shall be designed to maintain design recirculation flows under all conditions.	
Vacuum Limit Switches	4.7.1.8.2.4	Where vacuum filters are used, a vacuum limit switch shall be provided on the pump suction line.	
Maximum	4.7.1.8.2.5	The vacuum limit switch shall be set for a maximum vacuum of 18 inches (46 cm) of mercury.	
Pump Priming	4.7.1.8.2.6	All recirculation pumps shall be self-priming or flooded-suction.	
NPSH Requirement	4.7.1.8.2.7	All recirculation pumps shall meet the minimum NPSH requirement.	
Operating Gauges	4.7.1.8.3	<i>Operating Gauges</i>	
Vacuum Gauge	4.7.1.8.3.1	A compound vacuum-pressure gauge shall be installed on the pump suction line as close to the pump as possible.	
Suction Lift	4.7.1.8.3.2	A vacuum gauge shall be used for pumps with suction lift.	
Installed	4.7.1.8.3.3	A pressure gauge shall be installed on the pump discharge line adjacent to the pump.	
Easily Read	4.7.1.8.3.4	Gauges shall be installed so they can be easily read.	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
Valves	4.7.1.8.3.5	All gauges shall be equipped with valves to allow for servicing under operating conditions.	
Flow Measure and Control	4.7.1.9	Flow Measurement and Control	
Flow Meters	4.7.1.9.1	A flow meter accurate to within +/- 5% of the actual design flow shall be provided for each filtration system.	
Valves	4.7.1.9.2	All pumps shall be installed with a manual adjustable discharge valve to provide a backup means of flow control as well as for system isolation.	
Flow Rates / Turnover Times	4.7.1.10	Flow Rates/Turnover Times	
Maximum Allowable	4.7.1.10.1	All AQUATIC VENUES as defined in the MAHC shall comply with the following maximum allowable turnover times show in MAHC Table 4.7.1.10: "Maximum Allowable Turnover Times."	
Calculated	4.7.1.10.2	The turnover time shall be calculated based on the total volume of water divided by the flow rate through the filtration process.	
Unfiltered Water	4.7.1.10.2.1	Unfiltered water shall not factor into turnover time.	
Table 4.7.1.10		Table 4.7.1.10: Maximum Allowable Turnover Times	

Pool Type	Volume (Gallons)	Turnover (Hours)
Competition & Public Recreation	<200,000	4.0
	>=200,000	5.0
Apartment/Condo	ALL	5.0
Wave	<750,000	1.5
	>=750,000	2.0
Activity	<100,000	1.0
	>=100,000	1.5
Catch/Plunge	ALL	1.0
River & Vortex	<100,000	1.0
	>=100,000	1.5
Multi-Level Play Attractions	ALL	0.25
Spray Pad	ALL	0.17
Therapy	ALL	0.5
Wading	ALL	0.5

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
Turnover Variance	4.7.1.10.3	The AHJ may grant a turnover time variance for AQUATIC VENUES with extreme volume or operating conditions based on proper engineering justification.	
Turnover Times	4.7.1.10.4	Turnover times shall be calculated based solely on the flow rate through the filtration system.	
Required	4.7.1.10.4.1	The required turnover time shall be the lesser of the following options: 1) the specified time in MAHC Table 4.7.1.10, or 2) the time required for individual components (e.g., 3 skimmers with flow rates set by the manufacturer and an additional 20% for the floor drains could exceed the minimum value in the table).	
Total Volume	4.7.1.10.4.2	The total volume of the POOL system shall include the POOL and any surge/balance tank.	
Supply Water	4.7.1.10.4.3	Supply water to attractions (e.g., slides, lazy rivers, and tube rides) may be reused prior to filtration provided the DISINFECTANT and PH levels of the supply water are maintained at required levels.	
Secondary Disinfection	4.7.1.10.5	SECONDARY DISINFECTION SYSTEMS (e.g. UV or Ozone) for SPRAY PADS shall be installed on the total recirculation flow.	
Reuse Ratio	4.7.1.10.5.1	The ratio of AQUATIC FEATURE water to filtered water shall be no greater than 3:1 in order to maintain the efficiency of the FILTRATION SYSTEM.	
Flow Turndown System	4.7.1.10.6	For AQUATIC FACILITIES that intend to reduce the recirculation flow rate below the minimum required design values when the POOL is unoccupied, the flow turndown system shall be designed as follows in MAHC Section 4.7.1.10.6.1 to 4.7.1.10.6.3.	
Online Turbidimeter	4.7.1.10.6.1	A flow turndown system shall have an online turbidimeter capable of pulling water from the RECIRCULATION SYSTEM ahead of the filter.	
Linked	4.7.1.10.6.2	A flow turndown system shall have a VFD(s) linked to an online turbidimeter and the main RECIRCULATION SYSTEM flow meter(s).	
VFDs	4.7.1.10.6.3	A flow turndown system shall have a VFD(s) programmed to modify the system flowrate when the turbidity is less than the maximum allowable value.	
Flowrate	4.7.1.10.7	The system flowrate shall not be reduced more than 25% lower than the minimum design requirements and only reduced when	

Keyword	Section	Code	Grade
		the POOL is unoccupied.	
Turbidity	4.7.1.10.7.1	The system flowrate shall be based on maintaining a turbidity goal of less than 0.5 NTU in the POOL.	
Disinfectant Levels	4.7.1.10.7.2	The turndown system shall be required to maintain required DISINFECTANT and PH levels at all times.	
Increase	4.7.1.10.8	When the turndown system is also used to intelligently increase the recirculation flow rate above the minimum requirement (<i>e.g., in times of peak use to maintain water quality goals more effectively</i>), the following requirements shall be met at all times: <ol style="list-style-type: none"> 1) Velocity requirements inside of pipes (<i>per MAHC Section 4.7.1.7.2</i>), and 2) Maximum filtration system flows. 	
Filtration	4.7.2	Filtration	
Granular Media Filters	4.7.2.1	Granular Media Filters	
General	4.7.2.1.1	General	
Required	4.7.2.1.1.1	Filtration shall be required for all AQUATIC VENUES that recirculate water.	
Valves and Piping	4.7.2.1.1.2	The granular media filter system shall have valves and piping to allow isolation, venting, complete drainage (<i>for maintenance or inspections</i>), and backwashing of individual filters.	
Influent Pressure Gauge	4.7.2.1.1.3	Filtration accessories shall include the following items: <ol style="list-style-type: none"> 1) Influent pressure gauge, 2) Effluent pressure gauge, 3) Backwash sight glass (or viewing window), and 4) Manual air relief system. 	
Listed	4.7.2.1.1.4	All filters shall be currently listed in NSF/ANSI 50 – Equipment for Swimming Pools, Spas, Hot Tubs and Other Recreational Water Facilities (or an equivalent standard).	
Location and Spacing	4.7.2.1.2	Filter Location and Spacing	
Installed	4.7.2.1.2.1	Filters shall be installed with adequate clearance and facilities for ready and safe inspection, maintenance, disassembly, and repair.	

“This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy.”

Keyword	Section	Code	Grade
Media Removal	4.7.2.1.2.2	A means and access for easy removal of filter media shall be required.	
Rates	4.7.2.1.3	<i>Filtration and Backwashing Rates</i>	
Operate	4.7.2.1.3.1	High-rate granular media filters shall be designed to operate at no more than 12 gpm/ft ² (29.3 m/h).	
Backwash	4.7.2.1.3.2	The granular media filter system shall be designed to backwash each filter at a rate of at least 15 gallons per minute per square foot (36.7 m/h) of filter bed surface area, unless explicitly prohibited by the filter manufacturer or the NSF/ANSI 50 listing.	
Depth Requirements	4.7.2.1.4	<i>Filter Media Depth Requirements</i>	
Minimum	4.7.2.1.4.1	The minimum depth of filter media above the under-drains (or laterals) set by the filter manufacturer shall be used.	
Pressure	4.7.2.1.5	<i>Differential Pressure Measurement</i>	
Gauges	4.7.2.1.5.1	Influent and effluent pressure gauges shall have the capability to measure up to a 20 psi (138 KPa) increase in the differential pressure across the filter bed in increments of 1 psi (6.9 KPa) or less.	
Injection Equipment	4.7.2.1.6	<i>Coagulant Injection Equipment</i>	
Installed	4.7.2.1.6.1	If coagulant feed systems are used, they shall be installed with the injection point located ahead of the filters and recirculation pump(s) with electrical interlocks in accordance with MAHC Section 4.7.3.2.5.4.	
Precoat Filters	4.7.2.2	<i>Precoat Filters</i>	
General	4.7.2.2.1	<i>General</i>	
Listed	4.7.2.2.1.1	All precoat, filters (<i>i.e., pressure and vacuum</i>) shall be currently listed in NSF/ANSI 50 – Equipment for Swimming Pools, Spas, Hot Tubs and Other Recreational Water Facilities.	
Appropriate Media	4.7.2.2.1.2	Filters should be used with the appropriate filter media as recommended by the filter manufacturer for maximum clarity and cycle length.	
Filtration Rates	4.7.2.2.2	<i>Filtration Rates</i>	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
Vacuum Precoat	4.7.2.2.2.1	The design filtration rate for vacuum precoat filters shall not be either: <ol style="list-style-type: none"> 1) greater than 2.0 gallons per minute per square foot (4.9 m/h), or 2) 2.5 gpm/sf (6.1m/h) when used with a continuous precoat media feed (commonly referred to as “body-feed”). 	
Pressure Precoat	4.7.2.2.2.2	The design filtration rate for pressure precoat filters shall not be greater than 2.0 gallons per minute per square foot (4.9 m/h) of effective filter surface area.	
Introduction System	4.7.2.2.3	<i>Precoat Media Introduction System</i>	
Suction Side	4.7.2.2.3.1	A means shall be provided on the suction side of the pump for pressure precoat filter systems to introduce clean filter media while flowing water through the filter without return to the POOL (<i>unless filters are NSF Standard 50 certified to return water to POOL during the precoating process</i>).	
Continuous Feed	4.7.2.2.4	<i>Continuous Filter Media Feed Equipment</i>	
Manufacturer Specification	4.7.2.2.4.1	If equipment is provided for the continuous feeding of filter media to the filter influent, the equipment shall be used in accordance with the manufacturer’s specifications.	
Filter Media Discharge	4.7.2.2.4.2	All discharged filter media shall be handled in accordance with local and state laws, rules, and regulations.	
Filter Media	4.7.2.2.4.3	Diatomaceous earth or perlite shall be carefully graded and meet the media and filter manufacturer's recommendation for POOL use.	
NSF Standard	4.7.2.2.4.3.1	Diatomaceous earth or perlite shall be in accordance with NSF Standard 50.	
Alternate Types	4.7.2.2.4.4	Alternate types of filter media shall be permitted in accordance with the filter manufacturer's recommendation for POOL use.	
NSF Standard	4.7.2.2.4.4.1	Alternate types of filter media shall be in accordance with NSF Standard 50.	
Cartridge Filters	4.7.2.3	<i>Cartridge Filters</i>	
Listed	4.7.2.3.1	Cartridge filters shall be installed in accordance with the filter manufacturer's recommendations and with NSF Standard 50.	

“This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy.”

Keyword	Section	Code	Grade
Filtration Rates	4.7.2.3.2	The design filtration rate for surface-type cartridge filter shall not exceed 0.30 gallons per minute per square foot (0.20 L/s/m ²).	
Elements	4.7.2.3.3	Filter cartridges shall be supplied and sized in accordance with the filter manufacturer's recommendation for POOL use.	
Spare Cartridge	4.7.2.3.4	One complete set of spare cartridges shall be maintained on site in a clean and dry condition.	
Disinfection	4.7.3	Disinfection	
Chemical Addition	4.7.3.1	Chemical Addition Methods	
Disinfection and pH	4.7.3.1.1	DISINFECTION and PH control chemicals shall be automatically introduced through the RECIRCULATION SYSTEM	
Feeder	4.7.3.1.1.1	DISINFECTION and PH control chemicals shall be added using a feeder that meets the requirements outlined in MAHC Section 4.7.3.2.5.	
Mixing	4.7.3.1.2	Whenever required by the manufacturer, chemicals shall be diluted (or mixed with water) prior to application per the manufacturers' directions.	
Feed Equipment	4.7.3.2	Feed Equipment	
General	4.7.3.2.1	General	
Feeders & Devices	4.7.3.2.1.1	The POOL shall be equipped with chemical feed equipment that is tested and certified by an NRTL in conformance with ANSI/NSF Standard 50.	
Safe Condition	4.7.3.2.1.2	All chemical feed equipment shall be kept in safe working condition.	
Materials of construction	4.7.3.2.1.3	All feed equipment shall be of durable construction and of materials which resistant to the environment to which the parts will be subjected.	
Controls	4.7.3.2.1.4	All chemical feeders shall be provided with an automatic means to be disabled through an electrical interlock with at least two of the following: <ol style="list-style-type: none"> 1) Recirculation Pump Power, 2) Flow Meter/Flow switch in the return line, 	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
		3) Chemical Control Power and Paddle Wheel or Flow Cell on the chemical controller.	
<i>Installation</i>	4.7.3.2.1.5	The chemical feeders shall be installed according to the manufacturer's instructions.	
<i>Protective Cover</i>	4.7.3.2.1.5.1	A clear (Plexiglas) protective cover shall be installed around chemical feed pumps to shield operating staff and equipment from potential sprays from leaking connections.	
<i>Sizing</i>	4.7.3.2.2	<i>Sizing of Disinfection Equipment</i>	
<i>Sizing</i>	4.7.3.2.2.1	Feeders shall be capable of supplying disinfectant and PH control chemicals to the POOL to maintain the minimum required DISINFECTION levels at all times in accordance with the MAHC.	
<i>Chlorine Dosing</i>	4.7.3.2.2.2	All CHLORINE dosing and generating equipment including erosion feeders shall be sized to provide the following minimum dosage:	
		<ol style="list-style-type: none"> 1) Outdoor POOLS (unstabilized): 1.25lbs/day/FAC/10,000 gals. of POOL water. 2) Indoor POOLS: 1.0lbs/day/FAC/10,000 gals. of POOL water. 	
<i>High Use Facilites</i>	4.7.3.2.2.2.1	Feed equipment serving high use facilities such as water parks and high use health club facilities shall be sized to provide the following minimum dosage:	
		<ol style="list-style-type: none"> 1) Outdoor (unstabilized): 2.7lbs/day/FAC/10,000 gals. POOL water 2) Indoor: 1.25lbs/day/ FAC/10,000 gals. POOL water 	
<i>Rates</i>	4.7.3.2.2.3	The rates above are suggested minimums and in all cases the engineer shall validate the feed and production equipment specified.	
<i>Engineering</i>	4.7.3.2.3	<i>Feeder Engineering</i>	
<i>Positive Displacement</i>	4.7.3.2.3.1	All chemical adjustment feeders shall be positive displacement type such as diaphragm or peristaltic.	
<i>Engineering Justification</i>	4.7.3.2.3.2	The design professional shall provide engineering justification for the chemical feeder capacity requirements.	
<i>Introduction of Chemicals</i>	4.7.3.2.4	<i>Introduction of Chemicals</i>	
<i>Return Line</i>	4.7.3.2.4.1	All PH control chemicals, except coagulants if used, shall be fed	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
		into the return line after the pump, filters, and UV or ozone equipment, if provided.	
<i>Independent</i>	4.7.3.2.4.2	Injection of DISINFECTION chemicals shall be prior to filtration to reduce the likelihood of disinfectants and acidic chemicals mixing inside of pipes during periods of interruption to recirculation system flow.	
<i>Backflow</i>	4.7.3.2.4.3	Means of injection shall not allow BACKFLOW into the chemical system from the POOL system.	
<i>Coagulants</i>	4.7.3.2.4.4	Coagulants shall be metered and injected through a pump system prior to the filters per the manufacturer's recommended rate	
<i>Feeder Controls</i>	4.7.3.2.5	<i>Feeder Controls</i>	
<i>Automated</i>	4.7.3.2.5.1	Automated chemical feed control systems shall be used to turn on or off a chemical feeder.	
<i>Set Point</i>	4.7.3.2.5.2	A set point shall be used to target the disinfectant level and the PH level.	
<i>Manuals</i>	4.7.3.2.5.3	Operation manuals shall be provided that give clear directions for cleaning and calibrating the probes.	
<i>Compressed Chlorine Gas</i>	4.7.3.2.6	<i>Compressed Chlorine Gas</i>	
<i>Prohibited</i>	4.7.3.2.6.1	Use of compressed CHLORINE gas shall be prohibited for new construction and for after substantial alteration/modification to existing facilities.	
<i>Types of Feeders</i>	4.7.3.2.7	<i>Types of Feeders</i>	
<i>Liquid Solution Feeders</i>	4.7.3.2.7.1	Liquid solution feeders shall include positive displacement pumps such as peristaltic pumps, diaphragm pumps, and piston pumps.	
<i>Feed Rates</i>	4.7.3.2.7.1.1	Feed rates shall be locally adjusted on the pumps and also on/off controlled using timers or chemical controllers.	
<i>Dry Chemical Feeders</i>	4.7.3.2.7.2	Dry chemicals shall be granules or tablets.	
<i>Erosion</i>	4.7.3.2.7.3	Erosion feeders may be pressure, pressure differential, or spray erosion types.	
<i>Located</i>	4.7.3.2.7.3.1	Feeders located below POOL water level shall have isolation valves on each side of the feeder to be closed before opening the unit.	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
Source Water	5.7.3.2.7.5.2	Erosion feeders shall use venue water post-filtration as the source water unless approved by feeder manufacturer.	
Gas Feed Systems	4.7.3.2.7.4	Carbon dioxide and ozone use shall be permitted in AQUATIC FACILITIES.	
Ventilation	4.7.3.2.7.5	Proper ventilation shall be required for all gas systems.	
Chlorine Storage	4.7.3.2.7.5.1	One-minute or faster air exchange shall be provided in CHLORINE gas storage rooms.	
Location	4.7.3.2.7.6	CHLORINE gas systems shall be located at or above grade.	
UV Systems	4.7.3.2.7.7	Where used, Ultraviolet light (UV) systems shall be installed in the RECIRCULATION SYSTEM after the filters and before the heater and chemical feed connections.	
Bypass	4.7.3.2.7.7.1	A bypass pipe that is valved on both ends shall be installed to allow maintenance on the UV unit while the POOL is in operation.	
Interlock	4.7.3.2.7.7.2	UV system operation shall be interlocked with the recirculation pump.	
Strainer	4.7.3.2.7.7.3	An inline strainer shall be installed after the UV unit to capture broken lamp glass or sleeves.	
Electrolytic Generators	4.7.3.2.8	<i>Salt Electrolytic Chlorine Generators, Brine Electrolytic Chlorine or Bromine Generators</i>	
Salt Electrolytic Chlorine Generators	4.7.3.2.8.1	In-line generator(s) or brine (batch) generator(s) shall be permitted on AQUATIC VENUES.	
In-line method	4.7.3.2.8.2	In-line generators shall use salt dosed into the POOL to introduce CHLORINE into the POOL vessel through an electrolytic chamber.	
Batch method	4.7.3.2.8.3	Brine (Batch) generators shall produce CHLORINE through an electrolytic cell that is located in the mechanical room.	
TDS Readout	4.7.3.2.8.4	Electrolytic generators shall have a TDS readout and a low salt indicator.	
Feed Rate	4.7.3.2.8.5	The feed rate shall be adjustable from zero (0) to full range.	
Dosage	4.7.3.2.8.5.1	The generator shall be capable of feeding a CHLORINE dosage equivalent to four and one-half (4.5) pounds of available CHLORINE	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
		per day for each ten thousand (10,000) gallons of POOL capacity.	
Capacity	4.7.3.2.8.6	The generator(s) shall be capable of providing a CHLORINE dosage equivalent to 100% of the total daily facility requirement.	
UL Approved	4.7.3.2.8.7	The generator unit shall be UL listed and conform to NSF 50 or third party testing to the NSF Standard.	
Interlock	4.7.3.2.8.8	The generator(s) shall be interlocked per MAHC Section 4.7.3.2.1.4.	
Installed	4.7.3.2.8.9	The generator units shall be installed according to the manufacturer's instructions.	
Saline Content	4.7.3.2.8.9.1	The saline content of the POOL water shall be maintained in the required range specified by the manufacturer.	
Bromine	4.7.3.2.8.10	Bromine generators shall be NSF approved.	
Feeders	4.7.3.2.9	<i>Feeders for pH Adjustment</i>	
Provided	4.7.3.2.9.1	Feeders for PH adjustment shall be provided on all POOLS.	
Approved Substances	4.7.3.2.9.2	Approved substances for PH adjustment shall be Muriatic (Hydrochloric) Acid, Sodium Bisulfate, Carbon Dioxide, Sulfuric Acid, and Soda Ash.	
Prohibited	4.7.3.2.9.2.1	Sodium hydroxide use shall be prohibited.	
Positive Displacement	4.7.3.2.9.3	PH adjustment feeders shall be positive displacement type.	
Adjustable	4.7.3.2.9.4	PH adjustment feeders shall be adjustable from zero to full range.	
Solution Reservoirs	4.7.3.2.9.5	The solution reservoir's supply shall be a minimum of one week's supply.	
Marked	4.7.3.2.9.6	Reservoirs shall be clearly marked and labeled with contents.	
Controllers	4.7.3.2.10	<i>Controllers</i>	
NSF Listed	4.7.3.2.10.1	All chemical controllers for PH and disinfectant MONITORING/control shall conform to or be NSF 50 listed.	
Operation Manuals	4.7.3.2.10.2	Operation manuals that give clear directions for cleaning and calibrating controller probes shall be provided in the same room as the controller.	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
<i>Interlocked</i>	4.7.3.2.10.3	The generator(s) shall be interlocked per MAHC Section 4.7.3.2.5.4	
<i>Replenishment and Disposal</i>	4.7.4	Water Disposal and Replenishment System	
<i>Local Authority</i>	4.7.4.1	Waste streams generated by POOLS shall be properly discharged in accordance with state and local authorities.	
<i>Discharge and Measure</i>	4.7.4.2	A means of intentionally discharging and measuring the volume of both discharged POOL water and filter backwash wastewater (or alternate means of achieving the same result) shall be installed.	
<i>Alternate System</i>	4.7.4.2.1	An alternate system capable of removing an equivalent amount of small organic compounds and salts shall also be acceptable.	
<i>Product Water</i>	4.7.4.2.2	The product water from the alternate system shall maintain salt and total organic carbon concentrations that are less than or equal to tap water.	
<i>Discharge</i>	4.7.4.2.3	This system shall be designed to discharge (or treat and reuse) pool water at a rate of up to 4 gallons (15 L) per BATHER per day per AQUATIC VENUE.	
<i>Spas</i>	4.7.5	Spas	
<i>General</i>	4.7.5.1	General	
<i>Requirements</i>	4.7.5.1.1	Spas shall conform to the design, operation, and maintenance requirement of POOLS except as required below.	
<i>Flow Rates/ Turnover Times</i>	4.7.5.2	Flow Rates/Turnover Times	
<i>Maximum Allowable</i>	4.7.5.2.1	All SPA VENUES as defined in the MAHC shall comply with the following maximum allowable turnover times: 1) 0.25 hrs. for spa volumes less than 10,000 gallons or 2) 0.5 hrs. for spa volumes greater than or equal to 10,000 gallons	
<i>Calculated</i>	4.7.5.2.2	The turnover time shall be calculated based on the total volume of water divided by the flow rate through the filtration process.	
<i>Turnover Time Variance</i>	4.7.5.2.3	The AHJ may grant a turnover time variance for AQUATIC VENUES with extreme volume or operating conditions based on proper engineering justification.	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
Turnover Times	4.7.5.2.4	Turnover times shall be calculated based solely on the flow rate through the filtration system.	
Filtration Inlets	4.7.5.2	<i>Filtration System Inlets</i>	
Minimum	4.7.5.2.1	Spas shall have a minimum of two adjustable filter system INLETS spaced at least 3 feet (0.91 m) apart and designed to distribute flow evenly.	
Jet Inlets	4.7.5.3	<i>Jet System Inlets</i>	
Return Lines	4.7.5.3.1	The return lines of SPA type therapy or jet systems shall be independent of the recirculation-filtration and heating systems.	
Suction Lines	4.7.5.3.2	The suction lines for the jet or therapy INLETS shall be separate from the system of INLETS for the filtration/RECIRCULATION SYSTEM to prevent the filtration system flow rates from being reduced by the higher flows of the jet system.	
Air flow	4.7.5.3.3	Air flow shall be permitted through the jet system and/or when injected post-filtration.	
Skimmer	4.7.5.3.4	Submerged suction skimmers shall be allowed provided that the manufacturer's recommendations for use are followed.	
Adjustable Inlets	4.7.5.3.5	INLET velocities shall be adjustable.	
Return Jets	4.7.5.3.5.1	The velocities through the return jets shall not be restricted to swimming POOL INLET levels.	
Complete Draining	4.7.5.3.6	Piping shall be designed and installed such that complete draining of all water from the piping is readily achievable.	
VGB Drains	4.7.5.3.7	SPA floor and wall drain and recirculation fittings shall comply with the Federal VGB Act requirements.	

Model Aquatic Health Code
Recirculation Systems and Filtration Module Code
5.0 Operation and Maintenance

Keyword	Section	Code	Grade
	5.1	Plan Submittal	
	5.2	Materials	
	5.3	Equipment Standards	
	5.4	Pool Operation and Facility Maintenance	
	5.5	Pool Structure	
	5.6	Indoor/Outdoor Environment	
	5.7	Recirculation and Water Treatment	
<i>Systems & Equipment</i>	5.7.1	Recirculation Systems and Equipment	
<i>General</i>	5.7.1.1	General	
<i>Continuous Operation</i>	5.7.1.1.1	During operation all components of the filtration and RECIRCULATION SYSTEMS shall be kept in continuous operation (twenty-four (24) hours per day).	
<i>Flow</i>	5.7.1.1.2	Flow through the various components of a RECIRCULATION SYSTEM shall be balanced according to the provisions outlined in MAHC Section 5.7.1 to maximize the clarity and safety of a POOL.	
<i>Gutter/ Skimmer Pools</i>	5.7.1.1.3	For gutter or skimmer POOLS with main drains, the required recirculation flow shall be as follows during normal operation: <ol style="list-style-type: none"> 1) at least 80% of the flow through the perimeter overflow system and 2) no greater than 20% through the main drain. 	
<i>Combined Venue Treatment</i>	5.7.1.2	Combined Venue Treatment	
<i>Each Pool</i>	5.7.1.2.1	Each individual POOL in a combined treatment system shall meet the required turnover times and achieve all water quality criteria (including, but not limited to, PH, disinfectant concentration, and clarity/turbidity).	
<i>Inlets</i>	5.7.1.3	Inlets	
<i>Surface Skimming</i>	5.7.1.4	Surface Skimming Devices	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
Perimeter Overflow	5.7.1.4.1	The perimeter overflow systems shall be kept clean and free of debris that may restrict flow.	
Automatic Fill	5.7.1.4.2	The automatic fill system shall maintain the water level at an elevation such that the gutters must overflow continuously around the perimeter of the POOL.	
Automatic Fill	5.7.1.4.3	The automatic fill system shall maintain skimmer water levels near the middle of the skimmer openings when the POOL is unoccupied.	
Flow	5.7.1.4.4	The flow through each skimmer shall be adjusted as often as necessary to maintain skimming action that will remove all floating matter from the surface of the water.	
Strainer Baskets	5.7.1.4.5	The strainer baskets for skimmers shall be cleaned daily.	
Weirs	5.7.1.4.6	Broken or missing skimmer weirs shall be replaced immediately.	
Submerged Drains	5.7.1.5	Submerged Drains/Suction Outlet Covers or Gratings	
Replaced	5.7.1.5.1	Loose, broken, or missing suction outlet covers and sumps shall be secured or replaced immediately and installed in accordance with the manufacturer's requirements.	
Closed	5.7.1.5.1.1	POOLS shall be closed until the required repairs can be completed.	
Loose Covers	5.7.1.5.1.2	Loose covers shall be secured immediately according to the manufacturer's recommendations.	
Documentation	5.7.1.5.4	The manufacturer's documentation on all outlet covers and sumps shall be made part of the permanent records of the facility.	
Piping	5.7.1.6	Piping	
Strainers & Pumps	5.7.1.7	Strainers and Pumps	
Strainers	5.7.1.7.1	Strainers shall be in place and cleaned as required to maintain pump performance.	
Close/Open Procedures	5.7.1.7.3	Facilities shall follow procedures for closing and re-opening whenever required as outlined in MAHC Section 5.4.1.	
Flow Meters	5.7.1.8	Flow Meters	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
Maintained	5.7.1.8.1	Flow meters shall be maintained in an accurate operating condition.	
Flow Rates / Turnovers	5.7.1.9	Flow Rates/Turnovers	
Operated	5.7.1.9.1	Operated at the designed flow rate to provide the required turnover rate 24-hours per day except as allowed in MAHC Section 4.7.1.10.	
Filtration	5.7.2	Filtration	
Granular Media Filters	5.7.2.1	Granular Media Filters	
Filtration Rates	5.7.2.1.1	High-rate granular media filters shall be operated at no more than 12 gpm/ft ² (29.3 m/h).	
Backwashing Rates	5.7.2.1.2	The granular media filter system shall be backwashed at a rate of at least 15 gallons per minute per square foot (36.7 m/h) of filter bed surface area, unless explicitly prohibited by the filter manufacturer.	
Clear Water	5.7.2.1.3	Backwashing should be continued until the water leaving the filter is clear.	
Backwashing Frequency	5.7.2.1.4	All filters shall be backwashed at least twice per month.	
Backwashing	5.7.2.1.4.1	Backwashing of each filter shall be performed prior to reaching a 12 psi (83KPa) differential pressure increase over the initial clean filter pressure (<i>or as recommended by the filter manufacturer if this value is less</i>) unless the system can no longer achieve the design flow rate.	
Backwash Scheduling	5.7.2.1.4.2	Backwashes shall be scheduled to take place when the pool is closed for use or unless operators follow the procedure specified in MAHC Section 5.7.2.1.4.2.1.	
Backwashing While Open to Bathers	5.7.2.1.4.2.1	If the filter is backwashed while the AQUATIC FACILITY is open to BATHERS, then one of the following two procedures shall be performed after the normal backwashing procedure is completed and prior to the filter being placed back in normal operation:	
		<ol style="list-style-type: none"> 1) The filter flow shall be redirected to drain for a period of time sufficient to displace the volume of water inside of the filter or 3 minutes, whichever is greater, or 2) The backwash flow rate shall be reduced to a rate of no 	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
		greater than 5 gpm/ft ² (12.2 m/h) for a period of time sufficient to displace the volume of water inside of the filter.	
<i>Filter Media Inspections</i>	5.7.2.1.5	Sand or other granular media shall be inspected for proper depth and cleanliness at least one time per year.	
<i>Representative Filters</i>	5.7.2.1.5.2	The qualified operator shall inspect sand or other granular media filters for proper depth and cleanliness at least once per year.	
<i>Vacuum Sand Filters</i>	5.7.2.1.6	Vacuum sand filters shall be backwashed prior to a vacuum increase of 10 inches (254 mm) of mercury above the initial reading or as recommended by the manufacturer.	
<i>Air Release Valve</i>	5.7.2.1.6.1	The manual air release valve of the filter shall be opened as necessary to remove any air that collects inside of the filter as well as following each backwash.	
<i>Filtration Enhancing Products</i>	5.7.2.1.7	Products used to enhance filter performance shall be used according to manufacturers' recommendations.	
<i>Precoat Filters</i>	5.7.2.2	<i>Precoat Filters</i>	
<i>Appropriate</i>	5.7.2.2.1	The appropriate media type and quantity as recommended by the filter manufacturer shall be used.	
<i>Precoating</i>	5.7.2.2.2	Precoating of the filters shall be required in closed loop (precoat) mode to minimize the potential for media or debris to be returned to the POOL.	
<i>Operation</i>	5.7.2.2.3	Filter operation shall be per manufacturer and NSF standard requirements.	
<i>Uninterrupted Flow</i>	5.7.2.2.3.1	Flow through the filter shall not be interrupted when switching from precoat mode to filtration mode, which could result based on the order of opening and closing valves.	
<i>Maximum Precoat Media Load</i>	5.7.2.2.3.2	Systems designed to flow to waste while precoating shall use the maximum recommended precoat media load permitted by the filter manufacturer to account for media lost to the waste stream during precoating.	
<i>Cleaning</i>	5.7.2.2.4	The filter shall be cleaned/backwashed per manufacturer's instructions.	
<i>Continuous Feed</i>	5.7.2.2.5	Continuous filter media feed equipment tank agitators shall run	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
Equipment		continuously.	
Batch Application	5.7.2.2.5.1	Filter media feed may also be performed via batch application.	
Bumping	5.7.2.2.6	Bumping a precoat filter shall be performed in accordance with the manufacturer's recommendations.	
Filter Media	5.7.2.2.7	Precoat filter media shall meet the filter manufacturer's recommendation for POOL use and shall be in accordance with NSF Standard 50.	
Diatomaceous Earth	5.7.2.2.7.1	Diatomaceous earth (DE), when used, shall be added to precoat filters in the amount of 1 to 2 pounds (0.45 to 0.91 kg) per 10 square feet of filtration surface area.	
Perlite	5.7.2.2.7.2	Perlite, when used, shall be added to precoat filters in the amount of be used in the amount of 0.5 to 1 pounds (0.23 to 0.45 kg) per 10 ft ² (0.93 m ²) of filtration surface area.	
Cartridge Filters	5.7.2.3	Cartridge Filters	
NSF Standards	5.7.2.3.1	Cartridge filters shall be operated in accordance with the filter manufacturer's recommendation and NSF Standard 50.	
Filtration Rates	5.7.2.3.2	The maximum operating filtration rate for any surface-type cartridge filter shall not: <ol style="list-style-type: none"> 1) exceed 0.375 gallons per minute per square foot (0.26 L/s/m²) or 2) drop below 0.30 gallons per minute per square foot (0.20 L/s/m²). 	
Filter Elements	5.7.2.3.3	Active filter cartridges shall be exchanged with clean filter cartridges and fouled cartridges cleaned in accordance with the filter manufacturer's recommendations whenever the filtration rate drops below 0.30 gallons per minute per square foot (0.20 L/s/m ²).	
Cleaning Procedure	5.7.2.3.3.1	When the filter element manufacturer has no established cleaning procedure, the cleaning procedures found in MAHC Section 5.7.2.3.3.2 and 5.7.2.3.3.3 shall be used.	
Filter Housing Cleaning	5.7.2.3.3.2	The following procedures shall be implemented to clean the filter housing: <ol style="list-style-type: none"> 1) Drain filter housing to waste. 	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
		<ol style="list-style-type: none"> 2) Remove the filter cartridges from the housing. 3) Clean the inside of the filter with a brush and mild detergent prior to rinsing. 4) Mist the housing walls with chlorine bleach after scrubbing to remove biofilms and algae. 	
Cartridge Cleaning	5.7.2.3.3.3	The procedures outlined in this section shall be implemented to clean the filter cartridges when there is no cleaning procedure established by the filter manufacturer.	
Rinse Thoroughly	5.7.2.3.3.3.1	The cartridge shall be rinsed to remove as much dirt and debris as possible by washing inside and out with a garden hose and spray nozzle.	
Pressure Washer	5.7.2.3.3.3.2	A pressure washer shall not be used to backwash cartridge filters.	
Degrease	5.7.2.3.3.3.3	Cartridge filters shall be degreased each time they are cleaned per the procedures outlined in this section.	
Soak	5.7.2.3.3.3.3.1	<p>Soak the cartridge overnight in one of the following solutions:</p> <ol style="list-style-type: none"> 1) Filter cleaner/degreaser, or 2) A solution of water with 1 Cup of tri-sodium phosphate (TSP), or 3) 1 Cup of automatic dishwashing detergent per 5 gallons of water. 	
Acid	5.7.2.3.3.3.3.2	Muriatic acid or products with acid in them shall never be used prior to degreasing.	
Sanitize	5.7.2.3.3.3.4	To remove or prevent biofilms, algae, and bacteria growing on the cartridge, 1 quart of household bleach shall be added to the degreasing solution and soak one hour before rinsing.	
Rinse	5.7.2.3.3.3.5	The clean cartridge shall be removed from the soak water and rinsed thoroughly with a hose.	
Dry	5.7.2.3.3.3.6	After the filter is cleaned and degreased, it shall be allowed to dry completely before being reintroduced to the pool.	
Spare Cartridge	5.7.2.3.4	One full set of spare cartridges shall be maintained on site in a clean and dry condition.	
Water Clarity & Visibility	5.7.2.3.5	At all times, the visibility from any location on the DECK to the bottom of the deepest part of the POOL shall be sufficient to	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
		distinguish between adjacent 3-inch squares of different colors or the main drain grates.	
<i>Disinfection</i>	5.7.3	Disinfection	
<i>Chemical Addition</i>	5.7.3.1	Chemical Addition Methods	
<i>Manual Addition</i>	5.7.3.1.1	Chemicals added manually directly into the AQUATIC VENUE shall only be introduced in the absence of BATHERS.	
<i>Automatically</i>	5.7.3.1.2	Chemical additions, other than those added automatically to the recirculation piping, shall be introduced manually to the POOL through the surge or balance tank, skimmer, or by broadcasting into the POOL tank.	
<i>Super-chlorination</i>	5.7.3.1.2.1	Superchlorination or shock chemicals and other POOL chemicals added manually shall be introduced to the POOL through the surge tank, balance tank, or a skimmer whenever available.	
<i>Safety Requirements</i>	5.7.3.1.3	Whenever required by the manufacturer, chemicals shall be diluted (or mixed with water) prior to application and as per the manufacturer's directions.	
<i>Added</i>	5.7.3.1.3.1	Chemicals shall be added to water when diluting.	
<i>Mixed</i>	5.7.3.1.3.2	Chemicals shall be mixed in separate, labeled containers.	
<i>Stored</i>	5.7.3.1.3.3	All chemical containers shall be stored in a safe manner so as to prevent cross-mixing of chemicals, exposure to water, and as per relevant building codes.	
<i>Equipment maintenance</i>	5.7.3.1.4	POOL DISINFECTION and PH adjustment feed equipment shall be maintained in safe working condition at all times.	
<i>Chemical level maintenance</i>	5.7.3.1.4.1	POOL disinfectant and PH levels shall be maintained within the recommended ranges whenever the POOL is occupied.	
<i>Feed Equipment</i>	5.7.3.2	Feed Equipment	
<i>General</i>	5.7.3.2.1	General	
<i>Sizing</i>	5.7.3.2.2	Sizing of Disinfection Equipment	
<i>Engineering</i>	5.7.3.2.3	Feeder Engineering	
<i>Introduction</i>	5.7.3.2.4	Introduction of Chemicals	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
Controls	5.7.3.2.5	<i>Feeder Controls</i>	
Compressed Chlorine Gas	5.7.3.2.6	<i>Compressed Chlorine Gas</i>	
Stop Use	4.7.3.2.6.2	Facilities shall stop the use of CHLORINE gas if specific safety equipment and training requirements, along with local code considerations, cannot be met.	
Types	5.7.3.2.7	<i>Types of Feeders</i>	
Liquid Solution Feeders	5.7.3.2.7.1	For liquid solution feeders, spare feeder tubes (or tubing) shall be maintained onsite for peristaltic pumps.	
Checked Daily	5.7.3.2.7.1.1	Tubing and connections shall be checked on a daily basis for leaks.	
Routed	5.7.3.2.7.1.2	All chemical tubing shall be routed in PVC piping to support the tubing and to prevent leaks in areas where operating staff walk.	
Chemical Feeders	5.7.3.2.7.2	Chemical feeders shall be installed such that they are not over chemical storage containers, other feeders, or electrical equipment.	
Dry Chemical Feeders	5.7.3.2.7.3	Chemicals shall be kept dry to avoid clumping and potential feeder plugging for mechanical gate or rotating screw feeders.	
Cleaned and Lubricated	5.7.3.2.7.3.1	The feeder mechanism shall be cleaned and lubricated to maintain a reliable feed system.	
Venturi Inlet	5.7.3.2.7.4	Adequate pressure shall be maintained at the venturi INLET to create the vacuum needed to draw the chemical into the RECIRCULATION SYSTEM.	
Erosion Feeders	5.7.3.2.7.5	Erosion feeders shall only have chemicals added that are approved by the manufacturer.	
Opened	5.7.3.2.7.5.1	A feeder shall only be opened after the internal pressure is relieved by a bleed valve.	
Maintained	5.7.3.2.7.5.3	Erosion feeders shall be maintained according the manufacturer's instructions.	
Gas Feed Systems	5.7.3.2.7.6	The Chlorine Institute requirements for safe storage and use of CHLORINE gas shall be followed.	

Keyword	Section	Code	Grade
Carbon Dioxide	5.7.3.2.7.7	Carbon dioxide feed shall be permitted to reduce PH.	
Controlled	5.7.3.2.7.7.1	Carbon dioxide feed shall be controlled using a gas regulator.	
Fed	5.7.3.2.7.7.2	Carbon dioxide shall be fed using a venturi or a booster pump connected to the RECIRCULATION SYSTEM.	
Forced Ventilation	5.7.3.2.7.7.3	Carbon dioxide is heavier than air, so forced ventilation shall be maintained in the storage room.	
Electrolytic Generators	5.7.3.2.8	<i>Salt Electrolytic Chlorine Generators, Brine Electrolytic Chlorine or Bromine Generators</i>	
Maintained	5.7.3.2.8.1	Salt levels shall be maintained per the equipment manufacturer.	
Cleaning	5.7.3.2.8.2	Cleaning of electrolytic plates shall be performed as recommended by the manufacturer.	
Corrosion Protection	5.7.3.2.8.3	Corrosion protection systems shall be maintained in the POOL basin.	
Water Replenishment	5.7.4	Water Disposal and Replenishment	
Volume	5.7.4.1	Removal of water from the POOL and replacement with make-up water shall be performed as needed to maintain water quality.	
Discharged	5.7.4.2	A volume of water totaling at least to 4 gallons (15 L) per BATHER per day per facility shall be either <ol style="list-style-type: none"> 1) Discharged from the system, or 2) Treated with an alternate system meeting the requirements of MAHC Section 4.7.4.2.1 and reused. 	
Backwash Water	5.7.4.2.1	The required volume of water to be discharged may include backwash water.	
Multi-System Facilities	4.7.4.3	In multi-recirculation system facilities, WATER REPLENISHMENT shall be proportional to the number of BATHERS in each system.	
Spas	5.7.5	Spas	
Required Operation Time	5.7.5.1	SPA filtration systems shall be operated 24 hours per day except for periods of draining, filling, and maintenance.	
Drainage	5.7.5.2	SPAS shall be drained and cleaned when needed, but at least once every week.	

"This information is distributed solely for the purpose of pre dissemination public comment under applicable information quality guidelines. It has not been formally disseminated by the Centers for Disease Control and Prevention. It does not represent and should not be construed to represent any agency determination or policy."

Keyword	Section	Code	Grade
<i>Filtration System</i>	5.7.5.3	The backwash rate of sand filters shall be adjusted to match the temperature of the water used for backwashing.	
<i>Water Replacement</i>	5.7.5.4	Water shall be replaced at the required interval as outlined in MAHC Section 5.7.5.5.2.	
<i>Performed</i>	5.7.5.4.1	Water replacement shall be performed either all at once or incrementally on a daily basis.	
<i>Calculated</i>	5.7.5.4.2	The water replacement interval (in days) shall be calculated by dividing the SPA volume (in gallons) by 3 and then dividing by the average number of users per day.	
<i>Drained and Cleaned</i>	5.7.5.5	SPAS shall be drained and cleaned whenever needed.	
<i>Scrubbed</i>	5.7.5.5.1	SPA surfaces, including interior of skimmers, shall be scrubbed or wiped down, and all water drained prior to refilling at an interval not to exceed the water replacement interval.	

DRAFT