

Change Request Topic (Full CR, TRC review, member comment, and voting results at [https://cmahc.org/2015\\_change\\_requests.php](https://cmahc.org/2015_change_requests.php))

Change Request Number	PASS	Vote	Change Request Topic (Full CR, TRC review, member comment, and voting results at <a href="https://cmahc.org/2015_change_requests.php">https://cmahc.org/2015_change_requests.php</a> )
1	N		Define "raceway"
2	Y		adds missing word to increased risk facility definition
3	Y		edits pH definition
4	N		deletes definition for substantial alteration
5	Y		deletes section on variances
6	N		raising concern about lack of language on storing chlorine but no suggestion of what to add
7	Y		requires technical specs verify consultation with owner operator on air handling system
8	Y		plan should include zones of patron surveillance
9	Y		adds surf pool to occupancy listing
10	Y		clarification of wording on density factors
11	Y		swaps two sections on equipment replacement to make sequence clear
12	N		Removed wording to allow emergency replacement of equipment
13	N		deletes entire plan submittal section
14	N		question, no suggested language
15	Y		clarifies time for plumbed sink to be in existing facility diaper changing area
16	Y		clarifies time for plumbed sink to be in existing facility diaper changing area
17	Y		adds new section on installation of new features
18	N		requires a scale on multi-rider waterslides
19	Y		removes requirement for handholds if people required to be in tubes
20	Y		clarifies wording in section title
21	Y		adds new wording in multiple locations on slip resistance due to release of new standard
22	N		will require improvements in sound design
23	Y		clarifies language on design consultation with owner/operator
24	N		eliminates underwater benches in water over 3 feet deep
25	N		seeks to correct apparent discrepancy with spa seat and underwater bench depths
26	N		hydrotherapy jets not allowed at underwater benches
27	N		prohibits underwater shelves
28	N		sets maximum pool stair width to 5 feet
29	Y		Increases handrail heights
30	N		new section on float lines and warning stripes in zero depth entry pools
31	Y		wording clarifies electrical requirements apply to both indoor and outdoor facilities
32	Y		clarifies electrical language
33	Y		adds requirement for CO detectors
34	Y		surf pools added to turnover table
35	N.A.		N.A.
36	Y		clarifies when feeders required in existing facilities
37	Y		clarifies what type of chemicals can be used in flow-through feeders

38	Y	clarifies when electrical interlocks are required for existing facilities
39	N	sets performance standard for chlorine feeders
40	N	removes wording about "unstabilized" from feeder requirement
41	Y	requires labeling of halogen generators
42	Y	clarifies when controllers required
43	Y	requires secondary disinfection systems to be EPA labeled
44	N	adds annex language on use of secondary disinfection best practices
45	Y	adds wording on preventing mercury exposure
46	Y	corrects section title misspelling changes wording on ozone systems and where 3-log inactivation is measured
47	Y	
48	N	deletes water replenishment section deletes reference to a system to remove salts and leaves with organic material only
49	Y	
50	N	adds section on vacuum cleaners
51	N	sets limits on the use of wing walls
52	N	requires stairs for diving boards over 1 meter
53	Y	moves height of self closing latches to 4.5 ft.
54	Y	clarifies where eye wash station can be located
55	Y	clarifies about opening between chemical storage and rest of facility
56	N	deletes section on operating permits
57	Y	correct subsetting error on suits/towels
58	N	deletes section on inspections
59	N	allows shutoff of recirculation during certain times of facility closure
60	Y	clarifies when cracks are to be inspected or repaired
61	Y	clarifies wording on crack repair changes faculty to venue to clarify facility can stay open even if venue closed
62	Y	
63	Y	adds GFCI to underwater lighting operating with higher voltage
64	Y	consolidates lifeguarding language
65	Y	substitutes reduce likelihood vs. prevent slips/falls
66	Y	replaces waterslides with aquatic features since section generic
67	N	electrical issues discussed but no language submitted
68	Y	clarifies GFCI timing for testing
69	N	Increases time in between bonding inspections
70	N	adds wording about local plumbing code and potable water source
71	Y	consolidates wording on solid waste management
72	Y	consolidates wording on food preparation
73	Y	clarifying deck repair timing and reasons
74	N	Deletes wording about not having standing water on deck
75	N	Deletes requirement for 24 hour recirculation
76	Y	clarifies intent of backwash section
77	N	sets high water quality standards that if met allow chlorine level reduction
78	N	modifies upper chlorine level limit
79	Y	sets maximum bromine level adds annex language on why stabilizer should not be used in indoor settings
80	Y	

81	Y	Drops allowable cyanurate levels to 20 ppm
82	Y	Drops allowable CYA levels to 90 ppm so no dilutions are required to read
83	Y	Clarification: EPA registration required only if considered a pesticide
84	Y	Adds wording on feeder tubing protection for staff safety
85	Y	Clarifies supplemental treatment system language
86	Y	Language consolidation of sections
87	Y	Clarifies secondary disinfection language
88	N	Removes requirement that water samples are collected from different spots around pool
89	N	Raises combined chlorine action level to 1ppm
90	N.A.	N.A.
91	N	Alters wording from tripping hazards should be avoided to they should be inspected for adds wording about "if intended for patrons" to perimeter deck obstruction wording
92	N	
93	Y	changes wording from starting blocks to starting platforms Altering wording to allow alternate communication systems other than hardwired phone
94	N	Posting of sign in facilities with emergency personnel about communication devices
95	N	Posting of sign in facilities with emergency personnel about communication devices
96	N	
97	Y	clarifies heading on imminent health hazards adds wording storing chemicals in accordance with manufacturer recommendations
98	N	
99	N	administrative guidance deleted
100	N	repeat guidance on chemical storage
101	N	delete section 6 items on chemical use training
102	N	discusses respirator use but no suggested wording
103	Y	clarification on SDS vs. MSDS
104	Y	clarification on training and understanding health department roles adds new items to inspection list--emergency instructions and soap dispensers being
105	Y	fully stocked
106	N	Removes word "issues" for consistency
107	N	Makes course provider submit course information even if not required
108	Y	sentence shortening
109	Y	language consolidation
110	N	CMAHC to create list of lifeguard courses that meet MAHC qualifications
111	Y	lifeguard instructor courses should be taught by instructor trainers
112	Y	adds wording to lifeguard training to cover BVM use
113	Y	clarification about instructor actively administering lifeguard training clarification on when after lapse of lifeguard certificate requires a retake of course
114	Y	
115	Y	Requires certified instructor be present during lifeguard challenges
116	Y	clarification about instructor actively administering lifeguard training
117	N	Adding wording on revocation of lifeguard's certificate
118	N	Requires current lifeguard certification vs. past for lifeguard supervisors

		removes requirement for lifeguard supervisors to have had experience as a lifeguard (just the course)
119	N	
120	N	Changes sentence on scanning and vigilance requirements
121	Y	Addresses e-learning courses for lifeguards
		Clarifies that some lifeguard supervisor instructor pre-requisites are a subset of another
122	Y	
123	Y	Clarifies certification vs. certificate of completion
124	N	Requires lifeguard if alcohol served in facility
		clarifies requirements for facilities with lifeguards and number of guards on deck
125	Y	
126	N	clarifies lifeguard language in safety plan
127	N	In-Service training must be conducted by a qualified Lifeguard Instructor
128	N	Removes lifeguard proficiency requirements from in-service training
129	Y	adds wording to specify supervisor is a lifeguard supervisor
130	N.A.	N.A.
131	Y	clarifies language around guards wearing glasses and polarized glasses
132	Y	clarifies training on AED so equipment must be available
133	Y	adds reading materials to guard distractions not allowed
		adds wording to clarify that remote safety monitoring systems may aid but not replace a qualified lifeguard
134	N	
		adds wording to clarify that remote safety monitoring systems may aid but not replace a qualified lifeguard
135	N	
136	N	removes listing of daily inspection items
137	N	deletes 6 month bonding inspection
138	N	removes 24 hour time to inform AHJ about illness or injury
139	Y	clarifies illness and injury reports at "aquatic facility"
		Clarify the record keeping requirements for lifeguards. Rescues only vs. assists
140	Y	
141	Y	clarifies records for rescues
142	Y	clarifies bather count can be an estimate
143	Y	clarifies wording on bather use maximum and a plan for operation
144	N	deletes maximum capacity from bather load planning
145	Y	adds "rough play" to signage and prohibited activities
146	N	Removes theoretical peak occupancy from signage
147	Y	requires signs to add adult supervision for children
148	Y	reduces the items required on signs at multiple venue facilities
149	N	deletes signage language pertaining to facilities with multiple venues
150	N	Removes temperature variable from fecal incident response
151	N	no language change submitted
152	Y	Updates fecal incident response with new data from Murphy et al.
153	Y	alters wording about liability of operators
154	N	alters wording on operator liability
155	N	Removes wording about civil penalties
156	N	deletes entire inspection section
157	Y	edits acknowledgements section
158	Y	adds superscript to code sections having an annex explanation

159	Y	specifies which c codes are referenced within the code section vs mixing code and annex references
160	Y	corrects section numbering error
161	Y	corrects section numbering error
162	Y	clarifies wording in service animals on pool decks