

Inspection Checklist for NIH BL4 Animal Laboratories (7 CFR 331, 9 CFR 121, 42 CFR 73; BMBL 5th Edition)

Entity Name:

Inspection Date:

Building/Rooms:

Inspectors:

When information is entered in this form, the form is to be considered "Sensitive Select Agent Information."

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Laboratory animals involved in experiments requiring BL4 level physical containment shall be housed either in cages contained in Class III cabinets or in partial containment caging systems, such as Horsfall units (see Appendix G-III-K, Footnotes and References of Appendix G), open cages placed in ventilated enclosures, or solid-wall and -bottom cages placed on holding racks equipped with ultraviolet irradiation lamps and reflectors that are located in a specially designed area in which all personnel are required to wear one-piece positive pressure suits.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Non-human primates (NHP) may be housed (1) under the containment conditions described in Appendix G-II-D-2-I-(1) above, or (2) in open cages within a dedicated animal holding room that serves as the primary barrier and in which all personnel are required to wear one-piece positive pressure suits. A room serving as a primary barrier must be air-tight and capable of being decontaminated using fumigation.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (i) Access to the animal holding room from service corridors outside of the BL4 containment space shall require passage through two sets of doors, and the inner most door must be an air pressure resistant (APR) door;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (ii) For any animal holding room considered to be a primary barrier, APR door(s) providing direct ingress from the exterior service corridor shall be fitted with appropriate and redundant lock-out mechanisms to prevent access when the animal holding room is contaminated and in use. There should be more than one mechanism to ensure that this primary barrier door cannot be opened when the animal room is contaminated and the APR door shall not serve as an emergency exit from the BL4 laboratory. The APR door shall be appropriately tested to demonstrate that in the closed, locked-out mode, the door provides an air-tight barrier proven by pressure decay testing or other equivalent method;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (iii) Any door(s) allowing access into a corridor from which there is direct ingress to an animal holding room must be fitted with either (1) an APR door or (2) a non-APR door, provided directional airflow is maintained from the laboratory corridor space into the animal room. For the purpose of fumigation, animal rooms equipped with non-APR doors opening into the adjacent interior corridors shall be considered one space (i.e., areas between air-tight doors shall be fumigated together);	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (iv) Any door(s) used for access to the service corridor (the secondary barrier) shall be self-closing and of solid construction, designed not to corrode, split or warp;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (v) Access to the service corridor inside the secondary barrier shall be restricted and strictly controlled when animal rooms are in use. Whenever possible, the secondary barrier door(s) should be fitted with safety interlock switches designed to prevent it from opening when an animal holding room door (the primary barrier) is opened following room decontamination; if interlock devices cannot be used, specific administrative procedures shall be implemented to control access to the service corridor;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (vi) The service corridor shall maintain a negative pressure (inward directional airflow) relative to adjoining traffic corridors;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (vii) Prior to fumigation of the animal holding room, cages should be removed for autoclaving or chemical decontamination;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (viii) Caging should be chosen to reduce the amount of animal detritus that can be thrown out of the cage and onto the floor of the animal holding room;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (ix) The flow of personnel, material and equipment should be directed in order to minimize the spread of contamination from the animal holding room into adjacent areas of the laboratory;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (x) Following animal room decontamination, safeguards involving the use of personal protective equipment and appropriate administrative controls shall be implemented for the safe retrieval of biological indicators in order to prevent the spread of infectious agents in the event of a decontamination failure.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Experimental procedures involving a host-vector system that provides a one-step higher level of biological containment than that specified may be conducted in the BL4 facility using containment equipment requirements specified for the BL3 level of physical containment. Alternative combinations of containment safeguards are shown in Appendix G-Table 1, Possible Alternate Combinations of Physical and Biological Containment Safeguards.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	All procedures within the facility with agents assigned to Biosafety Level 4 are conducted in the Class III biological safety cabinet or in Class I or II biological safety cabinets used in conjunction with one-piece positive pressure personnel suits ventilated by a life-support system.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	The maximum containment facility consists of either a separate building or a clearly demarcated and isolated zone within a building. Outer and inner change rooms separated by a shower are provided for personnel entering and exiting the facility. A double-doored autoclave, fumigation chamber, or ventilated airlock is provided for passage of those materials, supplies, or equipment which are not brought into the facility through the change room.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Internal facility appurtenances, such as light fixtures, air ducts, and utility pipes, are arranged to minimize the horizontal surface area on which dust can settle.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Bench tops have seamless surfaces which are impervious to water and resistant to acids, alkalis, organic solvents, and moderate heat.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Laboratory furniture is simple and of sturdy construction; and spaces between benches, cabinets, and equipment are accessible for cleaning.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	A foot, elbow, or automatically operated hand washing sink is provided near the door of each laboratory room in the facility.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	If there is a central vacuum system, it does not serve areas outside the facility. In-line high efficiency particulate air/HEPA filters are placed as near as practicable to each use point or service cock. Filters are installed to permit in-place decontamination and replacement. Other liquid and gas services to the facility are protected by devices that prevent back-flow.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	If water fountains are provided, they are foot operated and are located in the facility corridors outside the laboratory. The water service to the fountain is not connected to the back-flow protected distribution system supplying water to the laboratory areas.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Access doors to the laboratory are self-closing and locking.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Any windows are breakage resistant.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	A double-door autoclave is provided for decontaminating materials passing out of the facility. The autoclave door which opens to the area external to the facility is sealed to the outer wall and automatically controlled so that the outside door can only be opened after the autoclave "sterilization" cycle has been completed.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	A pass-through dunk tank, fumigation chamber, or an equivalent decontamination method is provided so that materials and equipment that cannot be decontaminated in the autoclave can be safely removed from the facility.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Liquid effluent from laboratory sinks, biological safety cabinets, floors, and autoclave chambers are decontaminated by heat treatment before being released from the maximum containment facility. Liquid wastes from shower rooms and toilets may be decontaminated with chemical disinfectants or by heat in the liquid waste decontamination system. The procedure used for heat decontamination of liquid wastes is evaluated mechanically and biologically by using a recording thermometer and an indicator microorganism with a defined heat susceptibility pattern. If liquid wastes from the shower room are decontaminated with chemical disinfectants, the chemical used is of demonstrated efficacy against the target or indicator microorganisms.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	An individual supply and exhaust air ventilation system is provided. The system maintains pressure differentials and directional airflow as required to assure flows inward from areas outside of the facility toward areas of highest potential risk within the facility. Manometers are used to sense pressure differentials between adjacent areas maintained at different pressure levels. If a system malfunctions, the manometers sound an alarm. The supply and exhaust airflow is interlocked to assure inward (or zero) airflow at all times.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	<p>An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.</p>	<p>The exhaust air from the facility is filtered through high efficiency particulate air/HEPA filters and discharged to the outside so that it is dispersed away from occupied buildings and air intakes. Within the facility, the filters are located as near the laboratories as practicable in order to reduce the length of potentially contaminated air ducts. The filter chambers are designed to allow in situ decontamination before filters are removed and to facilitate certification testing after they are replaced. Coarse filters and HEPA filters are provided to treat air supplied to the facility in order to increase the lifetime of the exhaust HEPA filters and to protect the supply air system should air pressures become unbalanced in the laboratory.</p>	<ul style="list-style-type: none"> <input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A 	
12(a)	<p>An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.</p>	<p>The treated exhaust air from Class I and II biological safety cabinets may be discharged into the laboratory room environment or the outside through the facility air exhaust system. If exhaust air from Class I or II biological safety cabinets is discharged into the laboratory the cabinets are tested and certified at minimum on a yearly basis. More frequent testing and certification, based on the amount of use or other safety factors, shall be left to the discretion of the IBC. The exhaust air from Class III biological safety cabinets is discharged, without recirculation through two sets of high efficiency particulate air/HEPA filters in series, via the facility exhaust air system. If the treated exhaust air from any of these cabinets is discharged to the outside through the facility exhaust air system, it is connected to this system in a manner (e.g., thimble unit connection) that avoids any interference with the air balance of the cabinets or the facility exhaust air system.</p>	<ul style="list-style-type: none"> <input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A 	

Section	Regulation Text	Observation	Status	Comments
12(a)	<p>An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.</p>	<p>A specially designed suit area may be provided in the facility. Personnel who enter this area shall wear a one-piece positive pressure suit that is ventilated by a life-support system. The life-support system includes alarms and emergency backup breathing air tanks. Entry to this area is through an airlock fitted with airtight doors. A chemical shower is provided to decontaminate the surface of the suit before the worker exits the area. The exhaust air from the suit area is filtered by two sets of high efficiency particulate air/HEPA filters installed in series. A duplicate filtration unit, exhaust fan, and an automatically starting emergency power source are provided. The air pressure within the suit area is greater than that of any adjacent area. Emergency lighting and communication systems are provided. All penetrations into the internal shell of the suit are sealed. A double-doored autoclave is provided for decontaminating waste materials to be removed from the suit areas.</p>	<p><input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A</p>	
12(a)	<p>An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.</p>	<p>When an animal covered by Appendix Q containing recombinant or synthetic nucleic acid molecules or a recombinant or synthetic nucleic acid molecule-derived organism is euthanized or dies, the carcass shall be disposed of to avoid its use as food for human beings or animals unless food use is specifically authorized by an appropriate Federal agency.</p>	<p><input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A</p>	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	A permanent record shall be maintained of the experimental use and disposal of each animal or group of animals.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Individuals under 16 years of age shall not be permitted to enter the animal area.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	The containment area shall be locked.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	The containment area shall be patrolled or monitored at frequent intervals.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	The containment building shall be controlled and have a locking access.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	The Animal Facility Director shall establish policies and procedures whereby only persons who have been advised of the potential hazard and who meet any specific entry requirements (e.g., vaccination) may enter the laboratory or animal room.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Individuals shall enter and exit the animal facility only through the clothing change and shower rooms.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Personnel shall use the airlocks to enter or exit the laboratory only in an emergency.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Animal room doors, gates, and other closures shall be kept closed when experiments are in progress.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	All contaminated liquid or solid wastes shall be decontaminated before disposal.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	The work surfaces and containment equipment shall be decontaminated when work with organisms containing recombinant or synthetic nucleic acid molecules is finished. Where feasible, plastic-backed paper toweling shall be used on nonporous work surfaces to facilitate clean-up.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	All wastes from animal rooms and laboratories shall be appropriately decontaminated before disposal in an approved manner.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	No materials, except for biological materials that are to remain in a viable or intact state, shall be removed from the maximum containment laboratory unless they have been autoclaved or decontaminated. Equipment or material that might be damaged by high temperatures or steam shall be decontaminated by gaseous or vapor methods in an airlock or chamber designed for this purpose.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	When ventilated suits are required, the animal personnel shower entrance/exit area shall be equipped with a chemical disinfectant shower to decontaminate the surface of the suit before exiting the area. A neutralization or water dilution device shall be integral with the chemical disinfectant discharge piping before entering the heat sterilization system. Entry to this area shall be through an airlock fitted with airtight doors.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Needles and syringes shall be promptly placed in a puncture-resistant container and decontaminated, preferably by autoclaving, before discard or reuse.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Supplies and materials needed in the animal facility shall be brought in by way of the double-door autoclave, fumigation chamber, or airlock that shall be appropriately decontaminated between each use.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	<p>An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.</p>	<p>An autoclave, incinerator, or other effective means to decontaminate animals and wastes shall be available, preferably within the containment area. If feasible, a double-door autoclave is preferred and should be positioned to allow removal of material from the containment area.</p>	<p><input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A</p>	
12(a)	<p>An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.</p>	<p>Liquid effluent from containment equipment, sinks, biological safety cabinets, animal rooms, primary barriers, floor drains, and sterilizers shall be decontaminated by heat treatment before being released into the sanitary system. If required by design, regulation, local ordinance or policy, liquid wastes from shower rooms and toilets shall be decontaminated with chemical disinfectants or heat by methods demonstrated to be effective. The procedure used for heat decontamination of liquid wastes shall be monitored with a recording thermometer. The effectiveness of the heat decontamination process system shall be revalidated at minimum on a yearly basis with an indicator organism. More frequent validation, based on the amount of use or other safety factors, shall be left to the discretion of the IBC. If required by design, regulation, local ordinance or policy, liquid wastes from the shower shall be chemically decontaminated using an Environmental Protection Agency-approved germicide. The efficacy of the chemical treatment process shall be validated with an indicator organism. Chemical disinfectants shall be neutralized or diluted before release into general effluent waste systems.</p>	<p><input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A</p>	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	When the animal research requires special provisions for entry (e.g., vaccination), a warning sign incorporating the universal biosafety symbol shall be posted on all access doors to the animal work area. The sign shall indicate: (i) the agent, (ii) the animal species, (iii) the name and telephone number of the Animal Facility Director, or other responsible individual, and (iv) any special requirements for entering the laboratory.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Individuals shall enter and exit the animal facility only through the clothing change and shower rooms. Street clothing shall be removed and kept in the outer clothing change room. Complete laboratory clothing (may be disposable), including undergarments, pants, shirts, jump suits, and shoes shall be provided for all personnel entering the animal facility. When exiting the BL4-N area and before proceeding into the shower area, personnel shall remove their laboratory clothing in the inner change room. All laboratory clothing shall be autoclaved before laundering. Personnel shall shower each time they exit the animal facility.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	A ventilated head-hood or a one-piece positive pressure suit, which is ventilated by a life-support system, shall be worn by all personnel entering rooms that contain experimental animals when appropriate. When ventilated suits are required, the animal personnel shower entrance/exit area shall be equipped with a chemical disinfectant shower to decontaminate the surface of the suit before exiting the area. A neutralization or water dilution device shall be integral with the chemical disinfectant discharge piping before entering the heat sterilization system. Entry to this area shall be through an airlock fitted with airtight doors.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Appropriate respiratory protection shall be worn in rooms containing experimental animals.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Documents regarding experimental animal use and disposal shall be maintained in a permanent record book.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	A system shall be established for: (i) reporting laboratory accidents and exposures that are a result of overt exposures to organisms containing recombinant or synthetic nucleic acid molecules, (ii) employee absenteeism, and (iii) medical surveillance of potential laboratory-associated illnesses. Permanent records shall be prepared and maintained. Any incident involving spills and accidents that results in environmental release or exposures of animals or laboratory workers to organisms containing recombinant or synthetic nucleic acid molecules shall be reported immediately to the Biological Safety Officer, Animal Facility Director, Institutional Biosafety Committee, NIH OSP, and other appropriate authorities (if applicable). Reports to the NIH OSP shall be sent to the Office of Science Policy, National Institutes of Health, preferably by e-mail to: NIHGuidelines@od.nih.gov; additional contact information is also available here and on the OSP website (www.osp.od.nih.gov). Medical evaluation, surveillance, and treatment shall be provided as appropriate and written records maintained. If necessary, the area shall be appropriately decontaminated.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	When appropriate and giving consideration to the agents handled, baseline serum samples shall be collected and stored for animal care and other at-risk personnel. Additional serum specimens may be collected periodically depending on the agents handled or the function of the facility.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	A permanent record book indicating the date and time of each entry and exit shall be signed by all personnel.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	No materials, except for biological materials that are to remain in a viable or intact state, shall be removed from the maximum containment laboratory unless they have been autoclaved or decontaminated. Equipment or material that might be damaged by high temperatures or steam shall be decontaminated by gaseous or vapor methods in an airlock or chamber designed for this purpose.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Biological materials removed from the animal maximum containment laboratory in a viable or intact state shall be transferred to a non-breakable sealed primary container and then enclosed in a non-breakable sealed secondary container that shall be removed from the animal facility through a disinfectant dunk tank, fumigation chamber, or an airlock designed for this purpose. Advance approval for transfer of material shall be obtained from the Animal Facility Director. Such packages containing viable agents can only be opened in another BL4-N animal facility if the agent is biologically inactivated or incapable of reproduction. Special safety testing, decontamination procedures, and Institutional Biosafety Committee approval shall be required to transfer agents or tissue/organ specimens from a BL4-N animal facility to one with a lower containment classification.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Supplies and materials needed in the animal facility shall be brought in by way of the double-door autoclave, fumigation chamber, or airlock that shall be appropriately decontaminated between each use. After securing the outer doors, personnel within the animal facility retrieve the materials by opening the interior doors of the autoclave, fumigation chamber, or airlock. These doors shall be secured after materials are brought into the animal facility.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	All genetically engineered neonates shall be permanently marked within 72 hours after birth, if their size permits. If their size does not permit marking, their containers should be marked. In addition, transgenic animals should contain distinct and biochemically assayable DNA sequences that allow identification of transgenic animals from among non-transgenic animals.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Eating, drinking, smoking, and applying cosmetics shall not be permitted in the work area.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Individuals who handle materials and animals containing recombinant or synthetic nucleic acid molecules shall be required to wash their hands before exiting the containment area.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Experiments involving other organisms that require containment levels lower than BL4-N may be conducted in the same area concurrently with experiments requiring BL4-N containment provided that they are conducted in accordance with BL4-N practices.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Animal holding areas shall be cleaned at least once a day and decontaminated immediately following any spill of viable materials.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	All procedures shall be performed carefully to minimize the creation of aerosols.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	A double barrier shall be provided to separate male and female animals. Animal isolation barriers shall be sturdy and accessible for cleaning. Reproductive incapacitation may be used.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	The containment area shall be in accordance with state and Federal laws and animal care requirements.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	The life support system for the ventilated suit or head hood is equipped with alarms and emergency back-up air tanks. The exhaust air from the suit area shall be filtered by two sets of high efficiency particulate air/HEPA filters installed in series or incinerated. A duplicate filtration unit, exhaust fan, and an automatically starting emergency power source shall be provided. The air pressure within the suit shall be greater than that of any adjacent area. Emergency lighting and communication systems shall be provided. A double-door autoclave shall be provided for decontamination of waste materials to be removed from the suit area.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Needles and syringes shall be used only for parenteral injection and aspiration of fluids from laboratory animals and diaphragm bottles. Only needle-locking syringes or disposable syringe-needle units (i.e., needle is integral to the syringe) shall be used for the injection or aspiration of fluids containing organisms that contain recombinant or synthetic nucleic acid molecules. Extreme caution shall be used when handling needles and syringes to avoid autoinoculation and the generation of aerosols during use and disposal. Following use, needles shall not be bent, sheared, replaced in the needle sheath or guard, or removed from the syringe. The needles and syringes shall be promptly placed in a puncture-resistant container and decontaminated, preferably by autoclaving, before discard or reuse.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	An essential adjunct to the reporting-surveillance system is the availability of a facility for quarantine, isolation, and medical care of personnel with potential or known laboratory-associated illnesses.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	A biosafety manual shall be prepared or adopted. Personnel shall be advised of special hazards and required to read and follow instructions on practices and procedures.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Vacuum lines shall be protected with high efficiency particulate air/HEPA filters and liquid disinfectant traps.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Animals shall be contained within an enclosed structure (animal room or equivalent) to minimize the possibility of theft or unintentional release and avoid arthropod access.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	The interior walls, floors, and ceilings shall be impervious to water and resistant to acids, alkalis, organic solvents, and moderate heat, to facilitate cleaning. Penetrations in these structures and surfaces (e.g., plumbing and utilities) shall be sealed.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Windows in the animal facility shall be closed, sealed, and breakage resistant (e.g., double-pane tempered glass or equivalent).	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	An autoclave, incinerator, or other effective means to decontaminate animals and wastes shall be available, preferably within the containment area. If feasible, a double-door autoclave is preferred and should be positioned to allow removal of material from the containment area.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Access doors to the containment area shall be self-closing.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	All perimeter joints and openings shall be sealed to form an arthropod-proof structure.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	<p>An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.</p>	<p>The BL4-N laboratory provides a double barrier to prevent the release of recombinant or synthetic nucleic acid molecule containing microorganisms into the environment. Design of the animal facility shall be such that if the barrier of the inner facility is breached, the outer barrier will prevent release into the environment. The animal area shall be separated from all other areas. Passage through two sets of doors shall be the basic requirement for entry into the animal area from access corridors or other contiguous areas. Physical separation of the animal containment area from access corridors or other laboratories or activities shall be provided by a double-door clothes change room equipped with integral showers and airlock.</p>	<ul style="list-style-type: none"> <input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A 	
12(a)	<p>An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.</p>	<p>A necropsy room shall be provided within the BL4-N containment area.</p>	<ul style="list-style-type: none"> <input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A 	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Liquid effluent from containment equipment, sinks, biological safety cabinets, animal rooms, primary barriers, floor drains, and sterilizers shall be decontaminated by heat treatment before being released into the sanitary system. If required by design, regulation, local ordinance or policy, liquid wastes from shower rooms and toilets shall be decontaminated with chemical disinfectants or heat by methods demonstrated to be effective. The procedure used for heat decontamination of liquid wastes shall be monitored with a recording thermometer. The effectiveness of the heat decontamination process system shall be revalidated at minimum on a yearly basis with an indicator organism. More frequent validation, based on the amount of use or other safety factors, shall be left to the discretion of the IBC. If required by design, regulation, local ordinance or policy, liquid wastes from the shower shall be chemically decontaminated using an Environmental Protection Agency-approved germicide. The efficacy of the chemical treatment process shall be validated with an indicator organism. Chemical disinfectants shall be neutralized or diluted before release into general effluent waste systems.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	A ducted exhaust air ventilation system shall be provided that creates directional airflow that draws air into the laboratory through the entry area. The exhaust air, which is not recirculated to any other area of the building, shall be discharged to the outside and dispersed away from the occupied areas and air intakes. Personnel shall verify that the direction of the airflow (into the animal room) is proper.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Exhaust air from BL4-N containment area shall be double high efficiency particulate air/HEPA filtered or treated by passing through a certified HEPA filter and an air incinerator before release to the atmosphere. Double HEPA filters shall be required for the supply air system in a BL4-N containment area.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	All high efficiency particulate air/HEPA filters' frames and housings shall be certified to have no detectable smoke [dioctyl phthalate] leaks when the exit face (direction of flow) of the filter is scanned above 0.01 percent when measured by a linear or logarithmic photometer. The instrument must demonstrate a threshold sensitivity of at least 1×10^{-3} micrograms per liter for 0.3 micrometer diameter dioctyl phthalate particles and a challenge concentration of 80-120 micrograms per liter. The air sampling rate should be at least 1 cfm (28.3 liters per minute).	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	If an air incinerator is used in lieu of the second high efficiency particulate air/HEPA filter, it shall be biologically challenged to prove all viable test agents are sterilized. The biological challenge must be minimally 1×10^8 organisms per cubic foot of airflow through the incinerator. It is universally accepted if bacterial spores are used to challenge and verify that the equipment is capable of killing spores, then assurance is provided that all other known agents are inactivated by the parameters established to operate the equipment. Test spores meeting this criterion are <i>Bacillus subtilis</i> var. <i>niger</i> or <i>Bacillus stearothermophilus</i> . The operating temperature of the incinerator shall be continuously monitored and recorded during use.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	All equipment and floor drains shall be equipped with deep traps (minimally 5 inches). Floor drains shall be fitted with isolation plugs or fitted with automatic water fill devices.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Each animal area shall contain a foot, elbow, or automatically operated sink for hand washing. The sink shall be located near the exit door.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Restraining devices for animals may be required to avoid damage to the integrity of the containment animal facility.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	The supply water distribution system shall be fitted with a back-flow preventer or break tank.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	All utilities, liquid and gas services, shall be protected with devices that avoid back-flow.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(a)	An individual or entity required to register under this part must develop and implement a written biosafety plan that is commensurate with the risk of the select agent or toxin, given its intended use. The biosafety plan must contain sufficient information and documentation to describe the biosafety and containment procedures for the select agent or toxin, including any animals (including arthropods) or plants intentionally or accidentally exposed to or infected with a select agent. The current biosafety plan must be submitted for initial registration, renewal of registration, or when requested.	Sewer and other atmospheric ventilation lines shall be equipped minimally with a single high efficiency particulate/HEPA filter. Condensate drains from these type housings shall be appropriately connected to a contaminated or sanitary drain system. The drain position in the housing dictates the appropriate system to be used.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Laboratory animals involved in experiments requiring BL4 level physical containment shall be housed either in cages contained in Class III cabinets or in partial containment caging systems, such as Horsfall units (see Appendix G-III-K, Footnotes and References of Appendix G), open cages placed in ventilated enclosures, or solid-wall and -bottom cages placed on holding racks equipped with ultraviolet irradiation lamps and reflectors that are located in a specially designed area in which all personnel are required to wear one-piece positive pressure suits.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Non-human primates (NHP) may be housed (1) under the containment conditions described in Appendix G-II-D-2-I-(1) above, or (2) in open cages within a dedicated animal holding room that serves as the primary barrier and in which all personnel are required to wear one-piece positive pressure suits. A room serving as a primary barrier must be air-tight and capable of being decontaminated using fumigation.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (i) Access to the animal holding room from service corridors outside of the BL4 containment space shall require passage through two sets of doors, and the inner most door must be an air pressure resistant (APR) door;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (ii) For any animal holding room considered to be a primary barrier, APR door(s) providing direct ingress from the exterior service corridor shall be fitted with appropriate and redundant lock-out mechanisms to prevent access when the animal holding room is contaminated and in use. There should be more than one mechanism to ensure that this primary barrier door cannot be opened when the animal room is contaminated and the APR door shall not serve as an emergency exit from the BL4 laboratory. The APR door shall be appropriately tested to demonstrate that in the closed, locked-out mode, the door provides an air-tight barrier proven by pressure decay testing or other equivalent method;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (iii) Any door(s) allowing access into a corridor from which there is direct ingress to an animal holding room must be fitted with either (1) an APR door or (2) a non-APR door, provided directional airflow is maintained from the laboratory corridor space into the animal room. For the purpose of fumigation, animal rooms equipped with non-APR doors opening into the adjacent interior corridors shall be considered one space (i.e., areas between air-tight doors shall be fumigated together);	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (iv) Any door(s) used for access to the service corridor (the secondary barrier) shall be self-closing and of solid construction, designed not to corrode, split or warp;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (v) Access to the service corridor inside the secondary barrier shall be restricted and strictly controlled when animal rooms are in use. Whenever possible, the secondary barrier door(s) should be fitted with safety interlock switches designed to prevent it from opening when an animal holding room door (the primary barrier) is opened following room decontamination; if interlock devices cannot be used, specific administrative procedures shall be implemented to control access to the service corridor;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (vi) The service corridor shall maintain a negative pressure (inward directional airflow) relative to adjoining traffic corridors;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (vii) Prior to fumigation of the animal holding room, cages should be removed for autoclaving or chemical decontamination;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (viii) Caging should be chosen to reduce the amount of animal detritus that can be thrown out of the cage and onto the floor of the animal holding room;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (ix) The flow of personnel, material and equipment should be directed in order to minimize the spread of contamination from the animal holding room into adjacent areas of the laboratory;	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	If NHPs are to be contained in a dedicated animal holding room serving as the primary barrier, the following conditions shall be met: (x) Following animal room decontamination, safeguards involving the use of personal protective equipment and appropriate administrative controls shall be implemented for the safe retrieval of biological indicators in order to prevent the spread of infectious agents in the event of a decontamination failure.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Experimental procedures involving a host-vector system that provides a one-step higher level of biological containment than that specified may be conducted in the BL4 facility using containment equipment requirements specified for the BL3 level of physical containment. Alternative combinations of containment safeguards are shown in Appendix G-Table 1, Possible Alternate Combinations of Physical and Biological Containment Safeguards.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	All procedures within the facility with agents assigned to Biosafety Level 4 are conducted in the Class III biological safety cabinet or in Class I or II biological safety cabinets used in conjunction with one-piece positive pressure personnel suits ventilated by a life-support system.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	The maximum containment facility consists of either a separate building or a clearly demarcated and isolated zone within a building. Outer and inner change rooms separated by a shower are provided for personnel entering and exiting the facility. A double-doored autoclave, fumigation chamber, or ventilated airlock is provided for passage of those materials, supplies, or equipment which are not brought into the facility through the change room.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Walls, floors, and ceilings of the facility are constructed to form a sealed internal shell which facilitates fumigation and is animal and insect proof. The internal surfaces of this shell are resistant to liquids and chemicals, thus facilitating cleaning and decontamination of the area. All penetrations in these structures and surfaces are sealed. Any drains in the floors contain traps filled with a chemical disinfectant of demonstrated efficacy against the target agent, and they are connected directly to the liquid waste decontamination system. Sewer and other ventilation lines contain high efficiency particulate air/HEPA filters.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Internal facility appurtenances, such as light fixtures, air ducts, and utility pipes, are arranged to minimize the horizontal surface area on which dust can settle.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Bench tops have seamless surfaces which are impervious to water and resistant to acids, alkalis, organic solvents, and moderate heat.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Laboratory furniture is simple and of sturdy construction; and spaces between benches, cabinets, and equipment are accessible for cleaning.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	A foot, elbow, or automatically operated hand washing sink is provided near the door of each laboratory room in the facility.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	If there is a central vacuum system, it does not serve areas outside the facility. In-line high efficiency particulate air/HEPA filters are placed as near as practicable to each use point or service cock. Filters are installed to permit in-place decontamination and replacement. Other liquid and gas services to the facility are protected by devices that prevent back-flow.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	If water fountains are provided, they are foot operated and are located in the facility corridors outside the laboratory. The water service to the fountain is not connected to the back-flow protected distribution system supplying water to the laboratory areas.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Access doors to the laboratory are self-closing and locking.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Any windows are breakage resistant.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	A double-door autoclave is provided for decontaminating materials passing out of the facility. The autoclave door which opens to the area external to the facility is sealed to the outer wall and automatically controlled so that the outside door can only be opened after the autoclave "sterilization" cycle has been completed.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	A pass-through dunk tank, fumigation chamber, or an equivalent decontamination method is provided so that materials and equipment that cannot be decontaminated in the autoclave can be safely removed from the facility.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Liquid effluent from laboratory sinks, biological safety cabinets, floors, and autoclave chambers are decontaminated by heat treatment before being released from the maximum containment facility. Liquid wastes from shower rooms and toilets may be decontaminated with chemical disinfectants or by heat in the liquid waste decontamination system. The procedure used for heat decontamination of liquid wastes is evaluated mechanically and biologically by using a recording thermometer and an indicator microorganism with a defined heat susceptibility pattern. If liquid wastes from the shower room are decontaminated with chemical disinfectants, the chemical used is of demonstrated efficacy against the target or indicator microorganisms.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	An individual supply and exhaust air ventilation system is provided. The system maintains pressure differentials and directional airflow as required to assure flows inward from areas outside of the facility toward areas of highest potential risk within the facility. Manometers are used to sense pressure differentials between adjacent areas maintained at different pressure levels. If a system malfunctions, the manometers sound an alarm. The supply and exhaust airflow is interlocked to assure inward (or zero) airflow at all times.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	The exhaust air from the facility is filtered through high efficiency particulate air/HEPA filters and discharged to the outside so that it is dispersed away from occupied buildings and air intakes. Within the facility, the filters are located as near the laboratories as practicable in order to reduce the length of potentially contaminated air ducts. The filter chambers are designed to allow in situ decontamination before filters are removed and to facilitate certification testing after they are replaced. Coarse filters and HEPA filters are provided to treat air supplied to the facility in order to increase the lifetime of the exhaust HEPA filters and to protect the supply air system should air pressures become unbalanced in the laboratory.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	<p>The treated exhaust air from Class I and II biological safety cabinets may be discharged into the laboratory room environment or the outside through the facility air exhaust system. If exhaust air from Class I or II biological safety cabinets is discharged into the laboratory the cabinets are tested and certified at minimum on a yearly basis. More frequent testing and certification, based on the amount of use or other safety factors, shall be left to the discretion of the IBC.</p> <p>The exhaust air from Class III biological safety cabinets is discharged, without recirculation through two sets of high efficiency particulate air/HEPA filters in series, via the facility exhaust air system. If the treated exhaust air from any of these cabinets is discharged to the outside through the facility exhaust air system, it is connected to this system in a manner (e.g., thimble unit connection) that avoids any interference with the air balance of the cabinets or the facility exhaust air system.</p>	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	A specially designed suit area may be provided in the facility. Personnel who enter this area shall wear a one-piece positive pressure suit that is ventilated by a life-support system. The life-support system includes alarms and emergency backup breathing air tanks. Entry to this area is through an airlock fitted with airtight doors. A chemical shower is provided to decontaminate the surface of the suit before the worker exits the area. The exhaust air from the suit area is filtered by two sets of high efficiency particulate air/HEPA filters installed in series. A duplicate filtration unit, exhaust fan, and an automatically starting emergency power source are provided. The air pressure within the suit area is greater than that of any adjacent area. Emergency lighting and communication systems are provided. All penetrations into the internal shell of the suit are sealed. A double-doored autoclave is provided for decontaminating waste materials to be removed from the suit areas.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	When an animal covered by Appendix Q containing recombinant or synthetic nucleic acid molecules or a recombinant or synthetic nucleic acid molecule-derived organism is euthanized or dies, the carcass shall be disposed of to avoid its use as food for human beings or animals unless food use is specifically authorized by an appropriate Federal agency.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	A permanent record shall be maintained of the experimental use and disposal of each animal or group of animals.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Individuals under 16 years of age shall not be permitted to enter the animal area.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	The containment area shall be locked.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	The containment area shall be patrolled or monitored at frequent intervals.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	The containment building shall be controlled and have a locking access.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	The Animal Facility Director shall establish policies and procedures whereby only persons who have been advised of the potential hazard and who meet any specific entry requirements (e.g., vaccination) may enter the laboratory or animal room.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Individuals shall enter and exit the animal facility only through the clothing change and shower rooms.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Personnel shall use the airlocks to enter or exit the laboratory only in an emergency.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Animal room doors, gates, and other closures shall be kept closed when experiments are in progress.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	All contaminated liquid or solid wastes shall be decontaminated before disposal.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	The work surfaces and containment equipment shall be decontaminated when work with organisms containing recombinant or synthetic nucleic acid molecules is finished. Where feasible, plastic-backed paper toweling shall be used on nonporous work surfaces to facilitate clean-up.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	All wastes from animal rooms and laboratories shall be appropriately decontaminated before disposal in an approved manner.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	No materials, except for biological materials that are to remain in a viable or intact state, shall be removed from the maximum containment laboratory unless they have been autoclaved or decontaminated. Equipment or material that might be damaged by high temperatures or steam shall be decontaminated by gaseous or vapor methods in an airlock or chamber designed for this purpose.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	When ventilated suits are required, the animal personnel shower entrance/exit area shall be equipped with a chemical disinfectant shower to decontaminate the surface of the suit before exiting the area. A neutralization or water dilution device shall be integral with the chemical disinfectant discharge piping before entering the heat sterilization system. Entry to this area shall be through an airlock fitted with airtight doors.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Needles and syringes shall be promptly placed in a puncture-resistant container and decontaminated, preferably by autoclaving, before discard or reuse.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Supplies and materials needed in the animal facility shall be brought in by way of the double-door autoclave, fumigation chamber, or airlock that shall be appropriately decontaminated between each use.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	An autoclave, incinerator, or other effective means to decontaminate animals and wastes shall be available, preferably within the containment area. If feasible, a double-door autoclave is preferred and should be positioned to allow removal of material from the containment area.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Liquid effluent from containment equipment, sinks, biological safety cabinets, animal rooms, primary barriers, floor drains, and sterilizers shall be decontaminated by heat treatment before being released into the sanitary system. If required by design, regulation, local ordinance or policy, liquid wastes from shower rooms and toilets shall be decontaminated with chemical disinfectants or heat by methods demonstrated to be effective. The procedure used for heat decontamination of liquid wastes shall be monitored with a recording thermometer. The effectiveness of the heat decontamination process system shall be revalidated at minimum on a yearly basis with an indicator organism. More frequent validation, based on the amount of use or other safety factors, shall be left to the discretion of the IBC. If required by design, regulation, local ordinance or policy, liquid wastes from the shower shall be chemically decontaminated using an Environmental Protection Agency-approved germicide. The efficacy of the chemical treatment process shall be validated with an indicator organism. Chemical disinfectants shall be neutralized or diluted before release into general effluent waste systems.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	When the animal research requires special provisions for entry (e.g., vaccination), a warning sign incorporating the universal biosafety symbol shall be posted on all access doors to the animal work area. The sign shall indicate: (i) the agent, (ii) the animal species, (iii) the name and telephone number of the Animal Facility Director, or other responsible individual, and (iv) any special requirements for entering the laboratory.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Individuals shall enter and exit the animal facility only through the clothing change and shower rooms. Street clothing shall be removed and kept in the outer clothing change room. Complete laboratory clothing (may be disposable), including undergarments, pants, shirts, jump suits, and shoes shall be provided for all personnel entering the animal facility. When exiting the BL4-N area and before proceeding into the shower area, personnel shall remove their laboratory clothing in the inner change room. All laboratory clothing shall be autoclaved before laundering. Personnel shall shower each time they exit the animal facility.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	A ventilated head-hood or a one-piece positive pressure suit, which is ventilated by a life-support system, shall be worn by all personnel entering rooms that contain experimental animals when appropriate. When ventilated suits are required, the animal personnel shower entrance/exit area shall be equipped with a chemical disinfectant shower to decontaminate the surface of the suit before exiting the area. A neutralization or water dilution device shall be integral with the chemical disinfectant discharge piping before entering the heat sterilization system. Entry to this area shall be through an airlock fitted with airtight doors.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Appropriate respiratory protection shall be worn in rooms containing experimental animals.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Documents regarding experimental animal use and disposal shall be maintained in a permanent record book.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	A system shall be established for: (i) reporting laboratory accidents and exposures that are a result of overt exposures to organisms containing recombinant or synthetic nucleic acid molecules, (ii) employee absenteeism, and (iii) medical surveillance of potential laboratory-associated illnesses. Permanent records shall be prepared and maintained. Any incident involving spills and accidents that results in environmental release or exposures of animals or laboratory workers to organisms containing recombinant or synthetic nucleic acid molecules shall be reported immediately to the Biological Safety Officer, Animal Facility Director, Institutional Biosafety Committee, NIH OSP, and other appropriate authorities (if applicable). Reports to the NIH OSP shall be sent to the Office of Science Policy, National Institutes of Health, preferably by e-mail to: NIHGuidelines@od.nih.gov; additional contact information is also available here and on the OSP website (www.osp.od.nih.gov). Medical evaluation, surveillance, and treatment shall be provided as appropriate and written records maintained. If necessary, the area shall be appropriately decontaminated.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	When appropriate and giving consideration to the agents handled, baseline serum samples shall be collected and stored for animal care and other at-risk personnel. Additional serum specimens may be collected periodically depending on the agents handled or the function of the facility.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	A permanent record book indicating the date and time of each entry and exit shall be signed by all personnel.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	No materials, except for biological materials that are to remain in a viable or intact state, shall be removed from the maximum containment laboratory unless they have been autoclaved or decontaminated. Equipment or material that might be damaged by high temperatures or steam shall be decontaminated by gaseous or vapor methods in an airlock or chamber designed for this purpose.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Biological materials removed from the animal maximum containment laboratory in a viable or intact state shall be transferred to a non-breakable sealed primary container and then enclosed in a non-breakable sealed secondary container that shall be removed from the animal facility through a disinfectant dunk tank, fumigation chamber, or an airlock designed for this purpose. Advance approval for transfer of material shall be obtained from the Animal Facility Director. Such packages containing viable agents can only be opened in another BL4-N animal facility if the agent is biologically inactivated or incapable of reproduction. Special safety testing, decontamination procedures, and Institutional Biosafety Committee approval shall be required to transfer agents or tissue/organ specimens from a BL4-N animal facility to one with a lower containment classification.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Supplies and materials needed in the animal facility shall be brought in by way of the double-door autoclave, fumigation chamber, or airlock that shall be appropriately decontaminated between each use. After securing the outer doors, personnel within the animal facility retrieve the materials by opening the interior doors of the autoclave, fumigation chamber, or airlock. These doors shall be secured after materials are brought into the animal facility.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	All genetically engineered neonates shall be permanently marked within 72 hours after birth, if their size permits. If their size does not permit marking, their containers should be marked. In addition, transgenic animals should contain distinct and biochemically assayable DNA sequences that allow identification of transgenic animals from among non-transgenic animals.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Eating, drinking, smoking, and applying cosmetics shall not be permitted in the work area.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Individuals who handle materials and animals containing recombinant or synthetic nucleic acid molecules shall be required to wash their hands before exiting the containment area.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Experiments involving other organisms that require containment levels lower than BL4-N may be conducted in the same area concurrently with experiments requiring BL4-N containment provided that they are conducted in accordance with BL4-N practices.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Animal holding areas shall be cleaned at least once a day and decontaminated immediately following any spill of viable materials.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	All procedures shall be performed carefully to minimize the creation of aerosols.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	A double barrier shall be provided to separate male and female animals. Animal isolation barriers shall be sturdy and accessible for cleaning. Reproductive incapacitation may be used.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	The containment area shall be in accordance with state and Federal laws and animal care requirements.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	The life support system for the ventilated suit or head hood is equipped with alarms and emergency back-up air tanks. The exhaust air from the suit area shall be filtered by two sets of high efficiency particulate air/HEPA filters installed in series or incinerated. A duplicate filtration unit, exhaust fan, and an automatically starting emergency power source shall be provided. The air pressure within the suit shall be greater than that of any adjacent area. Emergency lighting and communication systems shall be provided. A double-door autoclave shall be provided for decontamination of waste materials to be removed from the suit area.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Needles and syringes shall be used only for parenteral injection and aspiration of fluids from laboratory animals and diaphragm bottles. Only needle-locking syringes or disposable syringe-needle units (i.e., needle is integral to the syringe) shall be used for the injection or aspiration of fluids containing organisms that contain recombinant or synthetic nucleic acid molecules. Extreme caution shall be used when handling needles and syringes to avoid autoinoculation and the generation of aerosols during use and disposal. Following use, needles shall not be bent, sheared, replaced in the needle sheath or guard, or removed from the syringe. The needles and syringes shall be promptly placed in a puncture-resistant container and decontaminated, preferably by autoclaving, before discard or reuse.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	An essential adjunct to the reporting-surveillance system is the availability of a facility for quarantine, isolation, and medical care of personnel with potential or known laboratory-associated illnesses.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	A biosafety manual shall be prepared or adopted. Personnel shall be advised of special hazards and required to read and follow instructions on practices and procedures.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Vacuum lines shall be protected with high efficiency particulate air/HEPA filters and liquid disinfectant traps.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Animals shall be contained within an enclosed structure (animal room or equivalent) to minimize the possibility of theft or unintentional release and avoid arthropod access.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	The interior walls, floors, and ceilings shall be impervious to water and resistant to acids, alkalis, organic solvents, and moderate heat, to facilitate cleaning. Penetrations in these structures and surfaces (e.g., plumbing and utilities) shall be sealed.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Windows in the animal facility shall be closed, sealed, and breakage resistant (e.g., double-pane tempered glass or equivalent).	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	An autoclave, incinerator, or other effective means to decontaminate animals and wastes shall be available, preferably within the containment area. If feasible, a double-door autoclave is preferred and should be positioned to allow removal of material from the containment area.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Access doors to the containment area shall be self-closing.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	All perimeter joints and openings shall be sealed to form an arthropod-proof structure.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	The BL4-N laboratory provides a double barrier to prevent the release of recombinant or synthetic nucleic acid molecule containing microorganisms into the environment. Design of the animal facility shall be such that if the barrier of the inner facility is breached, the outer barrier will prevent release into the environment. The animal area shall be separated from all other areas. Passage through two sets of doors shall be the basic requirement for entry into the animal area from access corridors or other contiguous areas. Physical separation of the animal containment area from access corridors or other laboratories or activities shall be provided by a double-door clothes change room equipped with integral showers and airlock.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	A necropsy room shall be provided within the BL4-N containment area.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Liquid effluent from containment equipment, sinks, biological safety cabinets, animal rooms, primary barriers, floor drains, and sterilizers shall be decontaminated by heat treatment before being released into the sanitary system. If required by design, regulation, local ordinance or policy, liquid wastes from shower rooms and toilets shall be decontaminated with chemical disinfectants or heat by methods demonstrated to be effective. The procedure used for heat decontamination of liquid wastes shall be monitored with a recording thermometer. The effectiveness of the heat decontamination process system shall be revalidated at minimum on a yearly basis with an indicator organism. More frequent validation, based on the amount of use or other safety factors, shall be left to the discretion of the IBC. If required by design, regulation, local ordinance or policy, liquid wastes from the shower shall be chemically decontaminated using an Environmental Protection Agency-approved germicide. The efficacy of the chemical treatment process shall be validated with an indicator organism. Chemical disinfectants shall be neutralized or diluted before release into general effluent waste systems.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	A ducted exhaust air ventilation system shall be provided that creates directional airflow that draws air into the laboratory through the entry area. The exhaust air, which is not recirculated to any other area of the building, shall be discharged to the outside and dispersed away from the occupied areas and air intakes. Personnel shall verify that the direction of the airflow (into the animal room) is proper.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Exhaust air from BL4-N containment area shall be double high efficiency particulate air/HEPA filtered or treated by passing through a certified HEPA filter and an air incinerator before release to the atmosphere. Double HEPA filters shall be required for the supply air system in a BL4-N containment area.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	All high efficiency particulate air/HEPA filters' frames and housings shall be certified to have no detectable smoke [dioctyl phthalate] leaks when the exit face (direction of flow) of the filter is scanned above 0.01 percent when measured by a linear or logarithmic photometer. The instrument must demonstrate a threshold sensitivity of at least 1x10 ⁻³ micrograms per liter for 0.3 micrometer diameter dioctyl phthalate particles and a challenge concentration of 80-120 micrograms per liter. The air sampling rate should be at least 1 cfm (28.3 liters per minute).	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	If an air incinerator is used in lieu of the second high efficiency particulate air/HEPA filter, it shall be biologically challenged to prove all viable test agents are sterilized. The biological challenge must be minimally 1x10 ⁸ organisms per cubic foot of airflow through the incinerator. It is universally accepted if bacterial spores are used to challenge and verify that the equipment is capable of killing spores, then assurance is provided that all other known agents are inactivated by the parameters established to operate the equipment. Test spores meeting this criterion are Bacillus subtilis var. niger or Bacillus stearothermophilus. The operating temperature of the incinerator shall be continuously monitored and recorded during use.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	All equipment and floor drains shall be equipped with deep traps (minimally 5 inches). Floor drains shall be fitted with isolation plugs or fitted with automatic water fill devices.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	

Section	Regulation Text	Observation	Status	Comments
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Each animal area shall contain a foot, elbow, or automatically operated sink for hand washing. The sink shall be located near the exit door.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Restraining devices for animals may be required to avoid damage to the integrity of the containment animal facility.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	The supply water distribution system shall be fitted with a back-flow preventer or break tank.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	All utilities, liquid and gas services, shall be protected with devices that avoid back-flow.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	
12(b)	The biosafety and containment procedures must be sufficient to contain the select agent or toxin (e.g., physical structure and features of the entity, and operational and procedural safeguards).	Sewer and other atmospheric ventilation lines shall be equipped minimally with a single high efficiency particulate/HEPA filter. Condensate drains from these type housings shall be appropriately connected to a contaminated or sanitary drain system. The drain position in the housing dictates the appropriate system to be used.	<input type="radio"/> No <input type="radio"/> Yes <input type="radio"/> N/A	